


# Compact 5-Port Solenoid Valve JSY1000/3000/5000 Series


### Plug-in







Can be connected with the ZK2 series vacuum unit p. 28 p. 28 p. 29 p. 20 p. 20









### The EX600-W series is compatible with wireless systems.

#### Noise resistance

- Uses the 2.4 GHz ISM frequency band
- · Frequency hopping: Every 5 ms

#### Communication cables not required

- · Reduced wiring work, space, and cost
- Minimized disconnection risk

#### High-speed connection

· From the remote power supply ON to start of communication: Min. 250 ms

#### Number of I/O points

 Max. 1280 inputs/1280 outputs (Max. 128 inputs/128 outputs per module)

#### Communication response

 Wireless communication signal Response time: 5 ms


#### Compatible protocols

EtherNet/IP




#### Application Examples

#### For tool changing



#### For rotary tables



### The EX260 series supports safety communication (PROFIsafe).

#### This is a Fieldbus unit which supports safety standard ISO 13849-compliant safety circuit constructions.

SMC



PROFIsafe is established as an international standard (IEC 61784-3-3). It is a communication protocol that transmits safety-related data by PROFINET communication and can be used up until safety standards ISO 13849-1 PL e and IEC 61508/IEC 62061 SIL 3.

#### Using the safety communication protocol

Refer to the EX260 Web Catalog for details on units that support the safety communication protocol.

When using a manifold valve within an ISO 13849-compliant safety system, the device needs to be considered from both the pneumatic circuit and the electric side.


Devices (including valves) need to be selected based on whether their functions are in line with the safety level of the equipment as a whole.

The use of valves that have been validated as being compliant with ISO 13849-2 may be required. For details on valves that have been validated, please contact SMC.


In addition, refer to "Safety Instructions" for precautions on model selection.



### Ejector can be mounted on a compact-size JSY1000 **DIGIN**



#### **Application Examples**



Separate fieldbus-compatible manifold JSY1000-E types are available to built-in pressure sensor and enable energy-saving control of ejector.




Valve manifold integrated with ejector system **JSY1000-E** 



### **Series Variations**

	Soni conducta					Port size 4(A), 2(B) port							
	C [dm <sup>3</sup> /(s. $4/2 \rightarrow 5$ $(A/B \rightarrow EA$ 4(A), 2(B) port	5/3ິ ]	lyne of actuation		Rated voltage	ø2	ø4	ø6	ø8	ø10	ø12	1(P), 3/5(E) port	
JSY1000	ø4	0.87	2-position single (A)4 2(B) (EA)5 1 3(EB) (P)	3-position pressure center (A)4 2(B) <u>MM_114-11</u> ZM2 (EA)513(EB) (P)		•	•					ø8	
	ø6			4-position dual 3-port valve N.C. valve x 2 pcs. 4(A) 2(B) 7(C) 1 (C) 1	.24			•				00	
JSY3000	ø8	2.77	3-position closed center (A)4 2(B) (CD)1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	N.O. valve x 2 pcs. 4(A) 2(B) 2(B) 5(EA) 1(P) 3(EB)	VDC			•	•			ø10	
JSY5000	ø12	6.59	3-position exhaust center (A)4 2(B) (CD)1 (CA)4 (CA)4 (EA)5 13(EB) (P)	N.C. valve, N.O. valve x 1 pc. of each 4(A) 2(B) TDI I I I I I I I I I I I I I I I I I I						•	•	ø12	

● Standard ○ Option ▲ Made to Order





	Wir	ing				Manifold	options	5				Va	lve optic	ons	
Pitch width [mm]	Positive common common	Negative common	Blanking plate	Individual SUP spacer	Individual EXH spacer	SUP stop valve spacer with residual pressure release valve	SUP/EXH blocking disk	Label for blocking disk	Silencer (One-touch fitting connection type)	Built-in silencer	Vacuum/Low- pressure specification	Different pressures	Reverse pressure	Mixed fitting sizes	Enclosure IP67*1
6.5						_									_
9	•	•	 p. 153	O p. 153	 p. 153	О р. 153-1	0 p. 154	0 p. 154	) p. 154	•	Eutomal	O	▲ Evtornol	•	
11.5			p. 155	p. 155	p. 155		p. 134	p. 134	p. 134		External pilot	Individual SUP	External pilot		•
16															•

\*1 Refer to "Manifold Specifications" on pages 38 and 39 for details on IP67.

#### SUP/EXH blocking disk

#### (For the connector type manifold, Type 10)

#### [SUP blocking disk]

Inserting an SUP blocking disk in the pressure supply passage of a manifold valve can allow for the use of 2 different pressures (high and low) in 1 manifold.

#### [EXH blocking disk]

Inserting an EXH blocking disk in the exhaust passage of a manifold valve can separate the exhaust from the valve so it does not affect the other valves. It can also be used in positive pressure and vacuum pressure mixed manifolds. (2 pieces are required to block both the EA and EB sides of the EXH.)




p. 154

#### **Manifold Options**


#### Labels for blocking disks

SUP/EXH









#### Specifications

Max. number of outputs: 32 (Valve + Ejector) Valve stations: 2 to 24 stations (Max. number of outputs: 30, Depends on whether single or double) Ejector stations: 1 to 8 stations (Max. number of outputs: 16)

#### Centralized wiring and piping directions

Wiring and piping for valves and ejectors can be arranged in the same direction. (Wiring method: Terminal block box and lead wire or EX250 and EX260)

# CONTENTS

Optimum Actuation Size Chart of	Air Cylinder	. 30 Plug-in Connec	tor Connecting Base	
Valve Specifications	, ,		-	p. 38
Response Time				p. 38
Valve Weight	p			p. 38
Valve Construction		. 36 ZK2 Combinatio	on Manifold Weight	
Valve Replacement Parts: Pilot Va	alve ····· p	. 37 Connector Wirir	ng Layout	
a second a few				
		State	· · · · · · · · · · · · · · · · · · ·	
D-sub connector Terminal b	lock box EX6	00	EX250	EX120
Flat ribbon cable	Lead wire	EX245	EX260	ZK2 combination manifold

...


#### D-sub Connector, Flat Ribbon Cable [IP20/40/67] How to Orde

How to Order p. 42
Dimensions
D-sub Connector (IP40/Connector Entry Direction Adjustable): F p. 44
D-sub Connector (IP67): FW p. 48
D-sub Connector (IP20/Compact Type): FC p. 50
Flat Ribbon Cable
(IP40/Connector Entry Direction Adjustable): P/PG/PH p. 53
Flat Ribbon Cable (IP20/Compact Type): PC/PGC/PHC p. 57
Electrical Wiring Specifications: D-sub Connector Cable
Electrical Wiring Specifications: Flat Ribbon Cable Connector p. 61
Spring Type Terminal Block Box, Terminal Block Box
How to Order p. 64
Dimensions
Spring Type Terminal Block Box: TC p. 66
Terminal Block Box: T p. 70
Connection/Electrical Wiring Specifications
Lead Wire
How to Order
Dimensions p. 78
Electrical Wiring Specifications p. 82
EX600 Integrated Type (For Input/Output)
Serial Transmission System
How to Order p. 84
Dimensions p. 86
EX245 Integrated Type (For Input/Output)
Serial Transmission System
How to Order p. 94
Dimensions p. 96
•
EX250 Integrated Type (For Input/Output) Serial Transmission System
How to Order p. 98
Dimensions p. 100
· · · · · ·
EX260 Integrated Type (For Output)
Serial Transmission System
How to Order p. 104
Dimensions p. 108
EX120 Integrated Type (For Output)
Serial Transmission System
How to Order p. 112
Dimensions p. 114

Type 10/Side Ported: Common Dimensions

Type Totelae Fortea. Common Dimensione	
(External Pilot, Built-in Silencer/Mixed Size, Straight Port Type) ····	p. 118
Manifold Exploded View [By Wiring]	p. 122
D-sub Connector/Flat Ribbon Cable	
(IP40/Connector Entry Direction Adjustable)	
D-sub Connector (IP67)	p. 124
D-sub Connector/Flat Ribbon Cable (IP20/Compact Type)	p. 125
Spring Type Terminal Block Box	
Terminal Block Box	p. 127
Lead Wire	
EX600	
EX245	p. 131
EX250	
EX260	
EX120	p. 135
Manifold Exploded View [Common Parts]	p. 136
Type 10: How to Increase Connector Type Manifolds	p. 136
For the JJ5SY1-10, JJ5SY3-10, JJ5SY5-10/	
Manifold Parts Nos.	p. 137
Vacuum Unit ZK2 Combination Manifold	
How to Order	p. 140
Dimensions	p. 144
ZK2 Combination Manifold Exploded View	p. 147
For the JJ5SY3-10-M (ZZK2□A)	p. 147
Manifold Parts Nos.	p. 148
ZK2 A Vacuum Ejector Manifold Exploded View	
How to Increase Manifold Stations	p. 149
	pe
One-touch Fittings, Plug, Clip, Port Plate,	
Tube Releasing Tool	p. 151
Manifold Options	
Made to Order	p. 156
Specific Product Precautions	p. 157


### For JSY1000, A, B port: Ø4



- \* The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.
- \* Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%
- \* Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.
- \* Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.


### For JSY1000, A, B port: Ø6





- \* Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.
- \* The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.
- \* Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%
- \* Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.
- \* Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.

### For JSY3000, A, B port: Ø8




- \* Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.
- \* The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.
- \* Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%
- \* Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.
- \* Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.



### For JSY5000, A, B port: Ø12





- \* The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.
- \* Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%
- \* Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.
- \* Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.

<sup>\*</sup> Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.

# JSY1000/3000/5000 Series Valve Specifications

#### Valve Specifications

Valve type			Rubber seal				
Fluid			Air				
	2-position sing	gle	0.15 to 0.7				
Internal pilot operating	2-position dou	ble	0.1 to 0.7				
pressure range [MPa]	3-position		0.2 to 0.7				
[WFa]	4-position dua	l 3-port valve	0.15 to 0.7				
External pilot	Operating pres	ssure range	-100 kPa to 0.7 (4-position: -100 kPa to 0.5)				
(Made to Order)	Pilot	2-position single/double	0.25 to 0.7				
operating pressure range	pressure	4-position dual 3-port valve*1	Operating pressure + 0.2 or more (Min. 0.25) to 0.7				
[MPa]	range	3-position	0.25 to 0.7				
Ambient and fluid temperation	Ambient and fluid temperatures [°C]		-10 to 50 (No freezing)				
		2-position single/double	5				
	JSY1000/3000	4-position dual 3-port valve	5				
Max. operating frequency		3-position	3				
[Hz]	JSY5000	2-position single/double	5				
		4-position dual 3-port valve	3				
		3-position	3				
			Non-locking push type				
Manual override			Push-turn locking slotted type				
			Push-turn locking lever type*2				
Pilot exhaust type	Internal pilot		Individual exhaust				
Filot exhaust type	External pilot	(Made to Order)					
Lubrication			Not required				
Mounting orientation*3			Unrestricted				
Impact/Vibration resistance	e*3 [m/s²]		150/30				
Enclosure			JSY1000: IP40 JSY3000/5000: IP67 (Based on IEC 60529)				
Coil rated voltage [DC]			24 V				
Allowable voltage fluctuati	on [V]		±10% of the rated voltage				
	Standard	JSY3000/5000	0.4				
Power consumption [W]	With nour	JSY1000	0.2*4 [Inrush 0.5, Holding 0.2]				
	With power- saving circuit	JSY3000/5000 (Made to Order)	0.1*5 [Inrush 0.4, Holding 0.1]				
Surge voltage suppressor			Diode (Varistor for non-polar type)				
Indicator light			LED				

. . . . . . . . . . . .

\*1 Only the JSY3000 can be selected for the 4-position dual 3-port valve external pilot specification.

\*2 Not available for the JSY1000 series

\*3 Impact resistance: No malfunction occurred when tested in the axial direction and at a right angle to the main valve and armature in both an energized and a de-energized state, once in each condition. (Value in the initial state) Vibration resistance: No malfunction occurred in a one-sweep test between 45 and 2000 Hz in the axial direction and at a right angle to the main valve and armature in both an energized and a de-energized state, once in each condition. (Value in the initial state) Refer to page 160 for details on securing the DIN rail mounting type manifold.

\*4 The JSY1000 series is only available as the power-saving type. Standard type (without power-saving circuit) cannot be selected.

\*5 For details, refer to page 158.

# Valve Specifications JSY1000/3000/5000 Series

#### **Response Time**

			Response time [ms]*1				
Series	Model	Type of actuation	With light/surge v	oltage suppressor			
			Z type	U type			
	JSY1100	2-position single	15				
JSY1000	JSY1200	2-position double	7				
JST1000	JSY13/4/500	3-position	16	_			
	JSY1A/B/C00	4-position dual 3-port valve	19				
	JSY3100	2-position single	27	18			
JSY3000	JSY3200	2-position double	13	12			
JS13000	JSY33/4/500	3-position	27	24			
	JSY3A/B/C00	4-position dual 3-port valve	23	23			
	JSY5100	2-position single	35	25			
JSY5000	JSY5200	2-position double	19	17			
0315000	JSY53/4/500	3-position	41	37			
	JSY5A/B/C00	JSY5A/B/C00 4-position dual 3-port valve		37			

\*1 Based on dynamic performance test, JIS B 8419-2010 (Coil temperature: 20°C, at rated voltage)

#### Valve Weight

#### **JSY1000 Series**

Valve model	Т	Weight [g]			
	O nonition	Single	24		
	2-position	Double	27		
JSY1⊡00		Closed center			
3311000	3-position	Exhaust center	30		
		Pressure center			
	4-position	Dual 3-port valve	27		

#### **JSY5000 Series**


Valve model	Т	Type of actuation			
	0 pesition	Single	91		
	2-position	Double	100		
JSY5⊓00		Closed center			
3315000	3-position	Exhaust center	110		
		Pressure center			
	4-position	Dual 3-port valve	96		

#### **JSY3000 Series**


Valve model	Т	ype of actuation	Weight [g]		
	2-position	Single	54		
	2-position	Double	63		
JSY3⊡00		Closed center			
JS13_00	3-position	Exhaust center	67		
		Pressure center			
	4-position	Dual 3-port valve	63		

# JSY1000/3000/5000 Series Valve Construction

#### **Rubber Seal**




3-position closed center/exhaust center/pressure center




#### **Component Parts**

No.	Description	Material
1	Body	Aluminum die-casted
2	Spool valve	Aluminum/HNBR (4-position solenoid valve: Resin/HNBR
3	Piston	Resin
4	Pilot valve assembly	_
36		



4-position dual 3-port valve




5(ÉA)

1(P)

3(EB)

# JSY3000/5000 Series Valve Replacement Parts: Pilot Valve

#### How to Order Pilot Valves (With a gasket and two mounting screws)\*




#### **∆**Caution

- The coil specification and voltage (including light/ surge voltage suppressor) cannot be changed by changing the pilot valve assembly.
- 2. When selecting the standard coil type, it is not possible to change to the power-saving circuit type.
- 3. Replacement pilot valve for the JSY3000/5000

How to replace pilot valves

Pilot valve assembly



- Loosen B tight flat head screw to remove the pilot cover in the direction indicated by the arrow (1).
- Remove the pilot valve mounting screws.
- Remove the pilot valve in the direction indicated by the arrow 2.
- \* Assemble by following the removal procedure in reverse.
- \*1 Ensure the gasket is mounted, and take care not to bend the socket.
- \*2 Be noted for mounting that there are two types of lengths for the pilot valve mounting screws.
- \*3 The pilot valve of the JSY1000 cannot be removed. This is irreplaceable.

JSY1000/3000/5000 <sub>Series</sub> Type 10 Plug-in Connector Connecting Base

#### **Manifold Specifications**

			D	-sub connect	or		Flat ribbon cable					
	Model		F type	FW type*1	FC type*2	P type	PG type	PH type	PC type*2	PGC type*2	PHC type*2	
Manifol	d type					Plug-in co	nnector conne	ecting base				
SUP/EX	(H port type				Co	mmon SUP/E	XH (Commor	n for the 3/5 p	ort)			
Valve s	tations			2 to 24	stations		2 to 18 stations	2 to 8 stations	2 to 24 stations	2 to 18 stations	2 to 8 stations	
Applicable connector			D-sub connector conforming to	Dedicated connector	D-sub connector conforming to				ble connecto 3503 (Refer to			
				(Refer to page 60.)	MIL-C-24308 (Refer to page 60.)	Socket: 26 pins MIL type	Socket: 20 pins MIL type	Socket: 10 pins MIL type	Socket: 26 pins MIL type	Socket: 20 pins MIL type	Socket: 10 pins MIL type	
Internal wiring			Positive common, Negative common									
		JSY1000		ø8 One-touch fitting								
	1(P), 3/5(E) port	JSY3000				ø10 One-touch fitting						
Port	port	JSY5000				ø12	2 One-touch fit	tting				
size		JSY1000			ø2 One-tou	uch fitting, ø4	One-touch fitt	ting, ø6 One-	touch fitting			
	4(A), 2(B) port	JSY3000			¢.	ø6 One-touch	n fitting, ø8 On	e-touch fitting	9			
	port	JSY5000			Ø	10 One-touch	n fitting, ø12 O	ne-touch fitti	ng			
Enclosure (Based on IEC 60529) JSY3000		JSY1000		_	IP20					IP20		
		JSY3000	IP40	IP67	1-20		IP40		1P20			
		JSY5000		11 07	_				_			

\*1 The FW type is not available for the JSY1000. Protection class for the JSY1000 is IP20 or IP40.

\*2 The FC, PC, PGC, and PHC types are not available for the JSY5000.

#### **Manifold Weight**

											Unit: g	
							② Wiring					
	Madal		D-sub connector			Flat ribbon cable						
Model		① Per station	F type	FW type*2	FC type*3	P type	PG type	PH type	PC type*3	PGC type*3	PHC type*3	
JSY1000	for ø4	21.3	308	-	233	306	304	298	233	231	225	
3511000	for ø6	26.9	319	-	244	317	315	309	244	242	236	
JSY3000	for ø8	42.7	332	330	287	330	328	322	257	255	249	
JSY5000	for ø12	104	509	507	-	507	505	499	—	-	—	

Formula for manifold weight\*1

W = 1 x n1 + 2 (n1: stations)

JSY3000 series, D-sub connector, F type, 5 stations: (42.7 x 5) + 332 = 545.5 (g)

#### **Manifold Flow Rate Characteristics**

	Port size		Valve flow rate characteristics						
Model	1, 3/5	4, 2	$1 \rightarrow 4/2 \ (P \rightarrow$	A/B)	$4/2 \rightarrow 3/5 (A/B)$	→ E)			
	(P, E)	(A, B)	C [dm <sup>3</sup> /(s·bar)]	b	C [dm3/(s·bar)]	b			
JJ5SY1-10	C8	C4	0.63	0.46	0.87	0.47			
(Side ported)		C6	0.96	0.30	0.91	0.48			
JJ5SY3-10 (Side ported)	C10	C8	2.23	0.30	2.77	0.27			
JJ5SY5-10 (Side ported)	C12	C12	6.40	0.22	6.59	0.22			

\* Calculation of effective area S and sonic conductance C: S = 5.0 x C

\* Values measured in accordance with ISO 6358:1989, JIS B 8390:2000

# Type 10 JSY1000/3000/5000 Series



							100
Terminal I	block box	Lead wire			Serial wiring		
T type	TC type	L type	S6□ type (EX600)	SA⊡ type (EX245)	S□ type (EX250)	S⊟ type (EX260)	S3□ type (EX120)
			Plug-in connector	connecting base			
		Сог	mmon SUP/EXH (Co	ommon for the 3/5 p	ort)		
2 to 20 stations			2 to 24	stations			2 to 16 stations
Positive common, Negative common     Negative common     Positive common, Negative common							
ø8 One-touch fitting							
ø10 One-touch fitting							
ø12 One-touch fitting							
ø2 One-touch fitting, ø4 One-touch fitting, ø6 One-touch fitting							
ø6 One-touch fitting, ø8 One-touch fitting ø10 One-touch fitting, ø12 One-touch fitting							
		Ø	TO One-touch fitting,	Ø 12 One-touch titti	ng		-
IP40							
	IP67		IP67 (I/O unit: partially IP40)	IP65	IP67	IP67 (D-sub communication connector: IP40)	IP20

 									Unit: g
(2) Wiring									
Terminal block box Lead wire					Serial wiring				
T type	TC type	L type (0.6 m)	L type (1.5 m)	L type (3 m)	S6□ type (EX600)*4	SA□ type (EX245)*4	S□ type (EX250)*4	S□ type (EX260)	S3□ type (EX120)
680	471	404	514	698	829		520	448	367
689	480	413	523	707	838		529	457	367
709	500	433	543	727	858	935	549	477	391
914	705	638	748	932	1063	1100	754	682	568

\*1 Weight: "W" is the value for the internal pilot specification, the max. fitting size, and the manifold only. The valve weight is not included. To obtain the weight with valves attached, add the valve weight given on page 35 for the appropriate number of stations.

\*2 The FW type is not available for the JSY1000.

\*3 The FC, PC, PGC, and PHC types are not available for the JSY5000.

\*4 The serial unit weight is included, but the I/O unit weight is not included. Add the weight of the I/O unit for calculation.

#### **ZK2** Combination Manifold Weight

#### Single Unit

Single unit model	Weight [g]
ZK2 (1 station for manifold, Without pressure sensor/switch)	99

#### Formula for ZK2 combination manifold weight

Wz = 1 x n1 + 2 + 3 x n2 + 3 (n1: JSY3000 stations, n2: ZK2 stations)

3
158
275
292

The weight "W2" is the value for the internal pilot specification, the max. fitting size, and the manifold only. To obtain the weight with valves and ejectors mounted, add the valve weight and the weight of the ejector, pressure sensor, and pressure switch for vacuum above, respectively, for the appropriate number of stations.




#### Pressure Sensor/Pressure Switch for Vacuum

Pressure sensor/Pressure switch for vacuum model	Weight [g]
ZK2-PSD-A (Excludes the cable portion weight)	5
ZK2-ZSD-A (Excludes the lead wire with connector weight)	14

#### **Connector Wiring Layout**

For both serial and parallel wiring, additional valves are sequentially assigned pins on the connector. This makes it completely unnecessary to disassemble the connector unit.



\* These diagrams are for the purpose of explanation, and differ from the actual connector wiring.



# Plug-in Connector Connecting Base


D-sub Connector Flat Ribbon Cable

Type 10 Side Ported

# **JSY1000/3000/5000** Series

Internal Pilot


How to Order Manifolds



U Series					
1	JSY1000				
3	JSY3000				
5	JSY5000				



4 Connector entry direction



6 P, E port entry						
U	U side (2 to 10 stations)					
D	D side (2 to 10 stations)					
В	Both sides (2 to 24 stations)					

The connector entry direction for connector types "FW," "FC," and "P□C" cannot be rotated. If it is necessary to
change, order connector block assembly and SUP/ EXH block assembly (pages 124 and 125) separately.

#### SUP/EXH block assembly

Nil	Internal pilot
s	Internal pilot,
3	Built-in silencer

- \* The 3/5(E) port is plugged for the built-in silencer type.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156

#### 8 A, B port size (Metric/One-touch fitting)

Symbol		A, B port	JSY1000	JSY3000	JSY5000	]
C2		ø2	۲	-	-	122
C4		ø4	•	_	_	
C6	Ĕ	ø6	۲	•	-	
C8	raight	ø8	—	•	-	
C10	Sti	ø10	—	_	•	Q. S. A
C12		ø12	-	_	•	00
CM*1		Straight port, mixed sizes	۲	•	•	- Or Cour
	P, E port size (One-touch fittings)		ø8	ø10	ø12	

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM." \* The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.


#### 9 Mounting and Option

Symbol	Mounting
Nil	Direct mounting
D	DIN rail mounting

#### 

DIN Rai	Option		
Nil	DIN rail	mounting (With DIN rail)	
		mounting (Without DIN rail)	
3	For 3 stations	Specify a length longer	
:	1	than that of the standard	
24	For 24 stations	rail.	

- Enter the number of stations inside 
  when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown on the left.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.




- \*1 FW is not available for the JSY1000.
- \*2 Compact type is not available for the JSY5000.

#### 5 Valve stations

F/FW	//FC: D	-sub connector (25 pins)	P/PC	: Flat	ribbon cable (26 pins)
Symbol	Stations	Note	Symbol	Stations	Note
02	2 stations		02	2 stations	
		Double wiring*1	:	1	Double wiring*1
12	12 stations		12	12 stations	
02	2 stations	Specified layout*2	02	2 stations	Specified layout*2
:		(Up to 24		:	(Up to 24
24	24 stations	solenoids available)	24	24 stations	solenoids available)
PG/P	GC: FI	at ribbon cable (20 pins)	PH/F	HC: FI	at ribbon cable (10 pins)
Symbol	Stations	Note	Symbol	Stations	Note
02	2 stations		02	2 stations	
:	:	Double wiring*1	:	:	Double wiring*1
09	9 stations	-	04	4 stations	-
02	2 stations	Specified layout*2	02	2 stations	Specified layout*2
:	:	(Up to 18	:	:	Up to 8
18	18 stations	solenoids available)	08	8 stations	solenoids available)

- \*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused
- control signal. If this is not desired, order with a specified layout. \*2 Specified layout: Indicate the wiring specifications on the manifold
- specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.) This also includes the number of blanking plates.

#### How to Order Manifold Assembly



#### B Pilot valve exhaust method

Pilot valve individual exhaust

#### 4 Rated voltage

5

24 VDC


1	0 nosition	Single						
2	2-position	Double						
3		Closed center						
4	3-position	Exhaust center						
5		Pressure center						
Α	4	N.C./N.C.						
в	4-position dual 3-port	N.O./N.O.						
С	dual 5-port	N.C./N.O.						

#### 5 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification
U			Non-polar
Z	•	•	Positive common
NZ			Negative common

 Only "Z" and "NZ" types are available for the JSY1000 series.

\* When the non-polar common specification type is selected, take measures to prevent surge voltage. For details, refer to page 159.



- Push-turn locking lever type "E" is not available for the JSY1000.
- When ordering a valve individually, the base gasket is not included. Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.




### **▲**Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156.

For the JSY1000 series, only the power-saving circuit specification is available.

### ∕ SMC




\* These figures show the "JJ5SY1-10F2-05D-C4."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	ension	IS												r	1: Stations
L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	96	102.5	109	115.5	122	128.5	135	141.5	148	154.5	161	167.5	174	180.5	187
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L4	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L5	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21
∕_n	17	18	19	20	21	22	23	24							
	193.5	200	206.5	213	219.5	226	232.5	239							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	223	235.5	248	248	260.5	260.5	273	273							
L4	212.5	225	237.5	237.5	250	250	262.5	262.5							
L5	18	21	24	20.5	23.5	20.5	23.5	20							
44							-								


# Connector Connecting Base JSY1000/3000/5000 Series



\* These figures show the "JJ5SY1-10F2-05D-C6."

- \* Refer to page 118 for dimensions of external pilot (Made to Order)and silencer.
- When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	ension	IS												r	1: Stations
_ _	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	101	110	119	128	137	146	155	164	173	182	191	200	209	218	227
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	135.5	148	160.5	160.5	173	185.5	185.5	198	210.5	223	223	235.5	248	248	260.5
L4	125	137.5	150	150	162.5	175	175	187.5	200	212.5	212.5	225	237.5	237.5	250
L5	20.5	22	24	19.5	21	23	18.5	20	22	23.5	19	21	22.5	18	20
$\sum n$	17	18	19	20	21	22	23	24							
L /	17	10	19	20	21	22	23	24							
L1	236	245	254	263	272	281	290	299							
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4							
L3	273	285.5	285.5	298	310.5	310.5	323	335.5							
L4	262.5	275	275	287.5	300	300	312.5	325							
L5	21.5	23.5	19	20.5	22.5	18	19.5	21.5							
							6	SMC							45




\* These figures show the "JJ5SY3-10F2-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	L: Dimensions n: Stations														
_ _	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	93.8	105.3	116.8	128.3	139.8	151.3	162.8	174.3	185.8	197.3	208.8	220.3	231.8	243.3	254.8
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275
L5	17.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5	23	23.5	18	18.5
L n	17	18	19	20	21	22	23	24							
L1	266.3	277.8	289.3	300.8	312.3	323.8	335.3	346.8							
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1							
L3	298	310.5	323	335.5	348	360.5	373	385.5							
L4	287.5	300	312.5	325	337.5	350	362.5	375							
L5	19	19.5	20	20.5	21	21.5	22	22.5							
46							Ø\$	SMC							

# Connector Connecting Base JSY1000/3000/5000 Series




\* These figures show the "JJ5SY5-10F2-05D-C12."

\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

#### I · Dimonsions

L: Dim	ension	IS												r	1: Stations
L _	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	139	155	171	187	203	219	235	251	267	283	299	315	331	347
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	185.5	210.5	223	235.5	260.5	273	285.5	298	323	335.5	348	360.5	385.5
L4	150	162.5	175	200	212.5	225	250	262.5	275	287.5	312.5	325	337.5	350	375
L5	22	20	18.5	23	21	19.5	24	22	20.5	18.5	23	21.5	19.5	18	22.5
L	17	18	19	20	21	22	23	24							
L1	363	379	395	411	427	443	459	475							
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5							
L3	398	410.5	435.5	448	460.5	473	498	510.5							
L4	387.5	400	425	437.5	450	462.5	487.5	500							
L5	20.5	19	23.5	21.5	20	18	22.5	21							
							Ø\$	SMC							47




\* These figures show the "JJ5SY3-10FW2-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	IS												r	1: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	108.6	120.1	131.6	143.1	154.6	166.1	177.6	189.1	200.6	212.1	223.6	235.1	246.6	258.1	269.6
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	148	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	298
L4	137.5	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	275	287.5	287.5
L5	22	16	16.5	17	17.5	18	18.5	19	19.5	20	20.5	21	21.5	22	16.5
		10	10												
L n	17	18	19	20	21	22	23	24							
L1	281.1	292.6	304.1	315.6	327.1	338.6	350.1	361.6							
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1							
L3	310.5	323	335.5	348	360.5	373	385.5	398							
L4	300	312.5	325	337.5	350	362.5	375	387.5							
L5	17	17.5	18	18.5	19	19.5	20	20.5							
48							<b>S</b> S	SMC							

# Connector Connecting Base JSY1000/3000/5000 Series




\* These figures show the "JJ5SY5-10FW2-05D-C12."

\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

#### I · Dimonsions

L: Dim	ension	IS												r	1: Stations
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	128	144	160	176	192	208	224	240	256	272	288	304	320	336	352
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	198	210.5	223	248	260.5	273	285.5	310.5	323	335.5	348	373	385.5
L4	150	162.5	187.5	200	212.5	237.5	250	262.5	275	300	312.5	325	337.5	362.5	375
L5	18.5	17	21.5	19.5	18	22.5	20.5	19	17	21.5	20	18	16.5	21	19
<hr/>															
L_n	17	18	19	20	21	22	23	24							
	17 368	<b>18</b> 384	<b>19</b> 400	<b>20</b> 416	<b>21</b> 432	<b>22</b> 448	<b>23</b> 464	<b>24</b> 480							
L1	368	384	400	416	432	448	464	480	]						
L1 L2	368 325.5	384 341.5	400 357.5	416 373.5	432 389.5	448 405.5	464 421.5	480 437.5	 						
L1 L2 L3	368 325.5 398	384 341.5 423	400 357.5 435.5	416 373.5 448	432 389.5 460.5	448 405.5 485.5	464 421.5 498	480 437.5 510.5	   						




\* These figures show the "JJ5SY1-10FC2-05D-C4."

 Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	ension	S												r	1: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	77.1	83.6	90.1	96.6	103.1	109.6	116.1	122.6	129.1	135.6	142.1	148.6	155.1	161.6	168.1
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198
L4	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5
L5	20	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18
<		40	10												
L_n	17	18	19	20	21	22	23	24							
L1	174.6	181.1	187.6	194.1	200.6	207.1	213.6	220.1							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	210.5	210.5	223	235.5	235.5	248	248	260.5							
L4	200	200	212.5	225	225	237.5	237.5	250							
L5	21	18	21	24	20.5	23.5	20.5	23.5							
50							Ø9	SMC							

# Eligent Connector Connecting Base JSY1000/3000/5000 Series




\* These figures show the "JJ5SY1-10FC2-05D-C6."

 Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

 When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	L: Dimensions n: Station														
L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	82.1	91.1	100.1	109.1	118.1	127.1	136.1	145.1	154.1	163.1	172.1	181.1	190.1	199.1	208.1
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	123	123	135.5	148	148	160.5	173	185.5	185.5	198	210.5	210.5	223	235.5	248
L4	112.5	112.5	125	137.5	137.5	150	162.5	175	175	187.5	200	200	212.5	225	237.5
L5	23.5	19	21	22.5	18	20	21.5	23.5	19	20.5	22.5	18	19.5	21.5	23
<u> </u>	17	18	19	20	21	22	23	24							
L1	217.1	226.1	235.1	244.1	253.1	262.1	271.1	280.1							
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4							
L3	248	260.5	273	285.5	285.5	298	310.5	310.5							
L4	237.5	250	262.5	275	275	287.5	300	300							
L5	18.5	20.5	22	24	19.5										
												51			




\* These figures show the "JJ5SY3-10FC2-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	L: Dimensions n: Stations														
L ^r	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	93.3	104.8	116.3	127.8	139.3	150.8	162.3	173.8	185.3	196.8	208.3	219.8	231.3	242.8	254.3
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	260.5	273	285.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	250	262.5	275
L5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5	23	23.5	17.5	18	18.5
L_n	17	18	19	20	21	22	23	24							
L1	265.8	277.3	288.8	300.3	311.8	323.3	334.8	346.3							
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1							
L3	298	310.5	323	335.5	348	360.5	373	385.5							
L4	287.5	300	312.5	325	337.5	350	362.5	375							
L5	19	19.5	20	20.5	21	21.5	22	22.5							
52															

# Connector Connecting Base JSY1000/3000/5000 Series



 When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	ension	IS												r	n: Stations
Ľ ^Ľ	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	96	102.5	109	115.5	122	128.5	135	141.5	148	154.5	161	167.5	174	180.5	187
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L4	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L5	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21
n	17	18	19	20	21	22	23	24	•						
	193.5	200	206.5	213	219.5	226	232.5	239							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	223	235.5	248	248	260.5	260.5	273	273	•						
L4	212.5	225	237.5	237.5	250	250	262.5	262.5							
L5	18	21	24	20.5	23.5	20.5	23.5	20	-						


**SMC** 


Applicable connector: 10 pins MIL type

(Conforming to MIL-C-83503)

Applicable connector: 20 pins MIL type

(Conforming to MIL-C-83503)






- \* These figures show the "JJ5SY1-10P2-05D-C6."
- Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- Only connectors are different for 10PG and 10PH. L1 to L5 dimensions are the same as 10P type.
- When CM is selected for mixed A, B port size, refer to page 121 for dimensions.


L: Dir	L: Dimensions n: Station															tations							
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	101	110	119	128	137	146	155	164	173	182	191	200	209	218	227	236	245	254	263	272	281	290	299
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	135.5	148	160.5	160.5	173	185.5	185.5	198	210.5	223	223	235.5	248	248	260.5	273	285.5	285.5	298	310.5	310.5	323	335.5
L4	125	137.5	150	150	162.5	175	175	187.5	200	212.5	212.5	225	237.5	237.5	250	262.5	275	275	287.5	300	300	312.5	325
L5	20.5	22	24	19.5	21	23	18.5	20	22	23.5	19	21	22.5	18	20	21.5	23.5	19	20.5	22.5	18	19.5	21.5

**SMC** 

# Connector Connecting Base JSY1000/3000/5000 Series



L: Din	L: Dimensions n: Stations															ations							
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	93.8	105.3	116.8	128.3	139.8	151.3	162.8	174.3	185.8	197.3	208.8	220.3	231.8	243.3	254.8	266.3	277.8	289.3	300.8	312.3	323.8	335.3	346.8
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275	287.5	300	312.5	325	337.5	350	362.5	375
L5	17.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5	23	23.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5




L: Dir	L: Dimensions n: S															tations							
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	123	139	155	171	187	203	219	235	251	267	283	299	315	331	347	363	379	395	411	427	443	459	475
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	160.5	173	185.5	210.5	223	235.5	260.5	273	285.5	298	323	335.5	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5
L4	150	162.5	175	200	212.5	225	250	262.5	275	287.5	312.5	325	337.5	350	375	387.5	400	425	437.5	450	462.5	487.5	500
1.5	22	20	18.5	23	21	19.5	24	22	20.5	18.5	23	21.5	19.5	18	22.5	20.5	19	23.5	21.5	20	18	22.5	21

Applicable connector: 10 pins MIL type

(Conforming to MIL-C-83503)


Applicable connector: 20 pins MIL type

(Conforming to MIL-C-83503)




#### I · Dimensions

L: Dim	ension	IS												r	1: Stations
  ⊐	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	72.1	78.6	85.1	91.6	98.1	104.6	111.1	117.6	124.1	130.6	137.1	143.6	150.1	156.6	163.1
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198
L4	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5
L5	25	28	24.5	27.5	24.5	27.5	24	27	24	27	23.5	26.5	23.5	26.5	23
<u>\</u> n	47	10	10		04			- 04							
L	17	18	19	20	21	22	23	24							
L1	169.6	176.1	182.6	189.1	195.6	202.1	208.6	215.1							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	210.5	210.5	223	235.5	235.5	248	248	260.5							
L4	200	200	212.5	225	225	237.5	237.5	250							
L5	26	23	26	29	25.5	28.5	25.5	28.5							
SMC															57



#### I · Dimensions

L: Dim	ension	IS												r	1: Stations
L _	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	77.1	86.1	95.1	104.1	113.1	122.1	131.1	140.1	149.1	158.1	167.1	176.1	185.1	194.1	203.1
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	123	123	135.5	148	148	160.5	173	185.5	185.5	198	210.5	210.5	223	235.5	248
L4	112.5	112.5	125	137.5	137.5	150	162.5	175	175	187.5	200	200	212.5	225	237.5
L5	28.5	24	26	27.5	23	25	26.5	28.5	24	25.5	27.5	23	24.5	26.5	28
<hr/>															
L	17	18	19	20	21	22	23	24							
L1	212.1	221.1	230.1	239.1	248.1	257.1	266.1	275.1							
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4							
L3	248	260.5	273	285.5	285.5	298	310.5	310.5							
L4	237.5	250	262.5	275	275	287.5	300	300							
L5	23.5	25.5	27	29	24.5	26	28	23.5							
58							<b>S</b>	SMC							




#### I. Dimonoiono

L: DIM	ension	IS												r	1: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	88.3	99.8	111.3	122.8	134.3	145.8	157.3	168.8	180.3	191.8	203.3	214.8	226.3	237.8	249.3
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275
L5	23	23.5	24	24.5	25	25.5	26	26.5	27	27.5	28	28.5	29	23	23.5
L n	17	18	19	20	21	22	23	24							
L1	260.8	272.3	283.8	295.3	306.8	318.3	329.8	341.3							
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1							
L3	298	310.5	323	335.5	348	360.5	373	385.5							
L4	287.5	300	312.5	325	337.5	350	362.5	375							
L5	24	24.5	25	25.5	26	26.5	27	27.5							
							6	SMC							59


#### **Electrical Wiring Specifications** Connector Cable 015 015 D-sub connector AXT100-DS25-030 [IP20/40] SY30M-DS25-030 [IP67] 050 050 If alignment is not specified, the internal Cable Cable 01 0.3 mm<sup>2</sup> x 25 cores 0.3 mm<sup>2</sup> x 25 cores 140 wiring will be double wiring 02 150 O.D. ø1.4 O.D. ø1.4 (connected to SOL. a and 03 04 SOL. b) regardless of Approx. ø10 170 H 05 number of stations, valve 180 190 06 Approx. ø8 types, and option types. 07 Seal (Length) 200 210 220 08 Connector terminal no. 010 Molded cover 230 240 011 012 Seal (Length) 250 2 x M2.6 x 0.45 013 44 38 Connector JBZ-25S-3 C Connector hood made by J.S.T. Mfg. T Co., Ltd. Polarity Terminal no. 2.4) 55 SOL.a 1 (-) (+)Socket side Station 1 { \_\_\_\_\_<u>SOL.b</u>\_\_\_\_14 2 x M2.6 x 0.45 14 .25 (-) (+) 86.5) SOL.a 2 Terminal no. (-) (+)[...... SOL.b 15 Station 2 (-) (+) SOL.a 3 (-) (+)1 ----<u>SOL.b</u>o 16 Station 3 47 04 (-) (+)SOL.a 4 (-) (+) Station 4 (-) (+) SOL.a Connector 5 (-) (+)SOL.b 18 Station 5 JBZ-25S-3 made by (-) (+) SOL.a J.S.T. Mfg. Co., Ltd. 6 (-) (+) SOL.b 19 Station 6 25 14 (-) (+)Socket side SOL.a 7 (-) (+) m Station 7 (-) (+) ..... SOL.a Terminal no. 8 (-) (+)Station 8 .....<u>SOL.b</u>o 21 (-) (+) 1 .13 SOL.a 47.04 9 (-) (+) SOL.b 22 Station 9 (-) (+) (-) (+) \_\_\_\_\_<u>SOL.b</u>o 23 D-sub connector cable [IP20/40 compliant] D-sub connector cable [IP67 compliant] Station 10 (-) (+)\_\_\_\_\_<u>SOL.a</u>\_\_\_\_11 Cable Cable Assembly part no. Assembly part no Note Note (-) (+)length (L length (L Station 11 (-) (+)SOL.a 12 1.5 m AXT100-DS25-015 1.5 m SY30M-DS25-015 (+)Cable (-) Cable Station 12 3 m AXT100-DS25-030 3 m SY30M-DS25-030 ......<u>SOL.b</u>o 25 (-) (+) 0.3 mm<sup>2</sup> x 25 cores 0.3 mm<sup>2</sup> x 25 cores AXT100-DS25-050 5 m SY30M-DS25-050 5 m C<u>OM.</u> 13 When using a standard commercial Be sure to use the connector cable in the (+) (-) connector, use a 25-pin type female table, to satisfy enclosure IP67 Positive Negative connector conforming to MIL-C-24308. \* Cannot be used for movable wiring common common Cannot be used for movable wiring I enotes other than the above are also When using a valve with no polarity, either positive available. Please contact SMC for details. common or negative common can be used. **Electrical characteristics** Specified Layout Item Property **Connector Manufacturer's Example** Conductor resistance 65 or less · Fujitsu Limited A mixture of single and double Ω/km, 20°C (25 pins) · Japan Aviation Electronics Industry, Limited wiring can be specified on the Voltage limit 1000 • J.S.T. Mfg. Co., Ltd. V, 1 minute, AC manifold specification sheet. HIROSE ELECTRIC CO., LTD. The maximum number of Insulation resistance -0 -0 5 or mor 140< MΩ/km, 20°C stations is determined according 150 0 3 0 4 0 5 0 7 0 8 0 7 0 8 0 7 0 8 0 7 0 8 0 7 0 8 0 11 0 11 0 11 160 170 180 200 210 220 230 240 to the number of solenoids. The The minimum bending radius total number of solenoids should of the D-sub connector cable is be 24 or less. 1 solenoid is 20 mm required for the 2-position D-sub connector cable terminal numbers single, and 2 solenoids for the Termina 2-position double, 3-position, Δ 7 10 11 14 250 2 3 5 6 8 9 12 13 15 16 17 18 19 20 21 22 23 24 25 no and 4-position. Orange Yellow Pink White Lead wire Black Brown Bed Blue Purple Gray White Yellow Orange Yellow Pink Blue Purple Gray Orange Red Brown Pink Gray Black White COM. color White Black Vhite None None None Vone None Vone None Vhite Black Black Bed Ped Jed **3lack** Slack None Vone Vhite Red Bed Vhite None Dot marking

\*


#### **Electrical Wiring Specifications**



#### Flat Ribbon Cable Connector



#### **Specified Layout**



A mixture of single and double wing can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 24 or less for P and PC, 18 or less for PG and PGC, and 8 or less for PH and PHC. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.



## Plug-in Connector Connecting Base


Spring Type Terminal Block Box **T** Terminal Block Box

Type 10 Side Ported

# **JSY1000/3000/5000** Series

Internal Pilot

### How to Order Manifolds



000	
1	JSY1000
3	JSY3000
5	JSY5000

### 4 Valve stations

TC:	TC: Spring type terminal block box T: Terminal block box												
Symbol	Stations	Note	Symbol	Stations	Note								
02	2 stations		02	2 stations									
:		Double wiring*1			Double wiring*1								
16	16 stations		10	10 stations									
02	2 stations	Specified layout*2	02	2 stations	Specified layout*2								
:	:	(Up to 32 solenoids	:	:	(Up to 20 solenoids								
24	24 stations	available)	20	20 stations	available)								

- \*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position
- valves cannot be used where single wiring has been specified.) \*3 This also includes the number of blanking plates.

### A, B port size (Metric/One-touch fitting)

Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	۲	—	-	12
C4		ø4	۲	—	-	
C6	ᆂ	ø6	۲	•	-	
C8	raight	ø8	-	•	-	
C10	l di	ø10	—	—	•	
C12		ø12	_	—	•	00
CM*1		Straight port, mixed sizes	۲	•	•	-O-Cour
		port size uch fittings)	ø8	ø10	ø12	

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

### B P. E port entry

TC

	1 2
U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 24 stations)

tade to Order

Spring type terminal block box Terminal block box

Made to Order (Refer to page 156 for details.) Specification External pilot (SUP/EXH block assembly)

### 6 SUP/EXH block assembly

Nil	Internal pilot
S	Internal pilot, Built-in silencer

\* The 3/5(E) port is plugged for the built-in silencer type.

- \* When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

### 8 Mounting and Option


Symbol	Mounting
Nil	Direct mounting
D	DIN rail mounting

- \* Enter the number of stations inside 
  when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.

#### **DIN Rail Option**

Nil	DIN ra	DIN rail mounting (With DIN rail)											
0	DIN rail	mounting (Without DIN rail)											
3	For 3 stations												
:	:	Specify a length longer than that of the standard rail.											
24	For 24 stations	that of the standard fail.											


### How to Order Manifold Assembly



For the JSY1000 series, only the power-saving circuit specification is available.

Protective class

class II (Mark: ())




\* These figures show the "JJ5SY1-10TC-05D-C4."

 Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	ension	IS												r	n: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	138.5	145	151.5	158	164.5	171	177.5	184	190.5	197	203.5	210	216.5	223	229.5
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5
L4	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5	250
L5	17.5	14	17	14	17	13.5	16.5	13.5	16.5	13	16	13	16	12.5	15.5
L n	17	18	19	20	21	22	23	24							
L1	236	242.5	249	255.5	262	268.5	275	281.5							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	260.5	273	273	285.5	285.5	298	310.5	310.5							
L4	250	262.5	262.5	275	275	287.5	300	300							
L5	12.5	15.5	12	15	12	15	18	14.5							
66							6	SMC							




\* These figures show the "JJ5SY1-10TC-05D-C6."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size, refer to page 121 for dimensions.


L: Dim	ension	ıs												r	n: Stations
_ ا	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	143.5	152.5	161.5	170.5	179.5	188.5	197.5	206.5	215.5	224.5	233.5	242.5	251.5	260.5	269.5
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	173	185.5	185.5	198	210.5	223	223	235.5	248	248	260.5	273	285.5	285.5	298
L4	162.5	175	175	187.5	200	212.5	212.5	225	237.5	237.5	250	262.5	275	275	287.5
L5	15	16.5	12	14	15.5	17.5	13	14.5	16.5	12	13.5	15.5	17	12.5	14.5
n	17	18	19	20	21	22	23	24							
L1	278.5	287.5	296.5	305.5	314.5	323.5	332.5	341.5							
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4							
L3	310.5	323	323	335.5	348	348	360.5	373							
L4	300	312.5	312.5	325	337.5	337.5	350	362.5							
L5	16	18	13.5	15	17	12.5	14	16							
							6	SMC							67



\* These figures show the "JJ5SY3-10TC-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	IS												r	: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	146.1	157.6	169.1	180.6	192.1	203.6	215.1	226.6	238.1	249.6	261.1	272.6	284.1	295.6	307.1
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5	298	310.5	323	335.5
L4	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275	287.5	300	312.5	325
L5	13.5	14	14.5	15	15.5	16	16.5	17	17.5	11.5	12	12.5	13	13.5	14
$\sum n$	17	18	10	20	21	22	23	24							
L /	17	10	19	20	21	22	23	24							
L1	318.6	330.1	341.6	353.1	364.6	376.1	387.6	399.1							
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1							
L3	348	360.5	373	385.5	398	410.5	423	423							
L4	337.5	350	362.5	375	387.5	400	412.5	412.5							
L5	14.5	15	15.5	16	16.5	17	17.5	12							
68							Ø9	SMC							




\* These figures show the "JJ5SY5-10TC-05D-C12."

\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L:	Dim	ensi	ions
		0110	

L: DIM	ension	IS												r	1: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5	325.5	341.5	357.5	373.5	389.5
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	198	210.5	223	248	260.5	273	285.5	310.5	323	335.5	360.5	373	385.5	398	423
L4	187.5	200	212.5	237.5	250	262.5	275	300	312.5	325	350	362.5	375	387.5	412.5
L5	16.5	14.5	13	17.5	15.5	14	12	16.5	15	13	17.5	16	14	12.5	17
L n	17	18	19	20	21	22	23	24							
L1	405.5	421.5	437.5	453.5	469.5	485.5	501.5	517.5							
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5							
L3	435.5	448	473	485.5	498	510.5	535.5	548							
L4	425	437.5	462.5	475	487.5	500	525	537.5							
L5	15	13.5	18	16	14.5	12.5	17	15.5							
							6	SMC							69



\* These figures show the "JJ5SY1-10T-05D-C4."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer. \* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included,

refer to page 121 for dimensions.

L: Dim	ension	IS												r	n: Stations
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	159.8	166.3	172.8	179.3	185.8	192.3	198.8	205.3	211.8	218.3	224.8	231.3	237.8	244.3	250.8
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	273	273	285.5
L4	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5	250	262.5	262.5	275
L5	13	16	13	16	13	16	12	15	12	15	12	15	18	15	18

	201.0	200.0
L2	153.9	160.4
L3	285.5	298
L4	275	287.5
L5	14	17
70		

257.3

18

263.8

19

270.3

166.9

287.5

14

298

20

276.8

173.4


310.5

300

17

 n 17

L1



\* These figures show the "JJ5SY1-10T-05D-C6."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	ension	IS												r	n: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	164.8	173.8	182.8	191.8	200.8	209.8	218.8	227.8	236.8	245.8	254.8	263.8	272.8	281.8	290.8
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	198	198	210.5	223	235.5	235.5	248	260.5	260.5	273	285.5	298	298	310.5	323
L4	187.5	187.5	200	212.5	225	225	237.5	250	250	262.5	275	287.5	287.5	300	312.5
L5	17	12	14	16	18	13	15	17	12	14	16	17	13	15	16
	47	10	10	00											
L	17	18	19	20											
L1	299.8	308.8	317.8	326.8											

d	u	r
 9	w	$\sim$

L2

L3 323

L4

L5

196.4

312.5

12

205.4

335.5

325

14

214.4

337.5

15


348

223.4

360.5

17

350



These figures show the "JJ5SY3-10T-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	IS												r	: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	167.4	178.9	190.4	201.9	213.4	224.9	236.4	247.9	259.4	270.9	282.4	293.9	305.4	316.9	328.4
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	198	210.5	223	235.5	248	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5
L4	187.5	200	212.5	225	237.5	237.5	250	262.5	275	287.5	300	312.5	325	337.5	350
L5	16	16	17	17	18	12	12	13	13	14	14	15	15	16	16
L n	17	18	19	20											
L1	339.9	351.4	362.9	374.4											
L2	238.6	250.1	261.6	273.1											

L3 373

L4

362.5

17

385.5

375

17

398


387.5

18

398

387.5

12




\* These figures show the "JJ5SY5-10T-05D-C12."

\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	S												r	1: Stations
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	186.8	202.8	218.8	234.8	250.8	266.8	282.8	298.8	314.8	330.8	346.8	362.8	378.8	394.8	410.8
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	210.5	235.5	248	260.5	285.5	298	310.5	323	348	360.5	373	398	410.5	423	435.5
L4	200	225	237.5	250	275	287.5	300	312.5	337.5	350	362.5	387.5	400	412.5	425
L5	12	16.5	14.5	13	17.5	15.5	14	12	16.5	15	13	17.5	16	14	12.5
		10	10												

L n	17	18	19	20
L1	426.8	442.8	458.8	474.8
L2	325.5	341.5	357.5	373.5
L3	460.5	473	485.5	498
L4	450	462.5	475	487.5
L5	17	15	13.5	11.5

### Spring Type Terminal Block "TC" Connection



### **Electrical Wiring Specifications (IP67 compliant)**

<b>B</b> 0	>	
2000000 ZZZZZZZ	azzzzzz	
0	e de si	]

If alignment is not specified, the internal wiring will be double wiring (connected to SOL. a and SOL. b) regardless of number of stations, valve types, and option types.

 When using a valve with no polarity, either positive common or negative common can be used.


	or comp	iunity			
s	tandard wir	ing			
		minal n	o. Pola	rity	
C	SOL.a	1A	(-)	(+)	
Station 1	SOL.b	1B	(-)	(+)	
0	SOL.a	2A	(-)	(+)	
Station 2	SOL.b	2B	(-)	(+)	
	SOL.a	3A	(-)	(+)	
Station 3	SOL.b	3B	(-)	(+)	
Ċ	SOL.a	4A	(-)	(+)	
Station 4	SOL.b	4B	(-)	(+)	
Ċ	SOL.a_o	5A	(-)	(+)	
Station 5	SOL.b	5B	(-)	(+)	
Ċ	SOL.a	6A	(-)	(+)	
Station 6	SOL.b	6B	(-)	(+)	
C	SOL.a_o	7A	(-)	(+)	
Station 7	SOL.b	7B	(-)	(+)	
C	SOL.a_o	8A	(-)	(+)	
Station 8	SOL.b	8B	(-)	(+)	
	SOL.a	9A	(-)	(+)	
Station 9	SOL.b	9B	(-)	(+)	
	SOL.a	10A	(-)	(+)	
Station 10	SOL.b	10B	(-)	(+)	
a	SOL.a	114	(-)	(+)	
Station 11	SOL.b	11B	(-)	(+)	
	SOL.a	124	(-)	(+)	
Station 12	SOL.b	12B	(-)	(+)	
0	SOL.a	13A	(-)	(+)	
Station 13	SOL.b	13B	(-)	(+)	
0	<u>SOL.a</u> o	14A	(-)	(+)	
Station 14	SOL.b	14B	(-)	(+)	
Station 15	SOL.a	15A	(-)	(+)	
Station 15	<u>SOL.b</u> o	15B	(-)	(+)	
Charling to S	SOL.a		(-)	(+)	
Station 16	SOL.b	16B	(–)	(+)	
	o	COM.	(+)	(-)	
	0	COM.	(+)	(-)	
		1	Positive N	legative	
		c	common c	ommon	

Specified Layout

A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 32 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.

		0	⊳
	B AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA		
14B 15B 16B 00M		3	
		0	

#### **Terminal Block "T" Connection**




#### **Electrical Wiring Specifications (IP67 compliant)**

	Standard	wiri	ng	
		minal	no. Pola	arity
	Station 1 {	1A 1B	(-) (-)	(+) (+)
	Station 2	2A 2B	(-)	(+)
	Station 3 SOL.a	ЗA	(-) (-)	(+) (+)
	Station 4	3B 4A	(–) (–)	(+) (+)
	Station 5	4B 5A	(-) (-)	(+) (+)
	Station 6	5B 6A	(-) (-)	(+) (+)
	Station 7 SOL.a	6B 7A	(-) (-)	(+) (+)
If alignment is not specified, the	Station 8 SOL.a	7B 8A 8B	(-) (-)	(+) (+)
internal wiring will be double wiring (connected to SOL. a and SOL. b)	Station 9 SOL.a	9A 9B	(-) (-) (-)	(+) (+)
regardless of number of stations, valve types, and option types.	Station 10 SOL.a	10A 10B	(-)	(+) (+)
* When using a valve with no		TOB	(-) (+)	(+) (-)
polarity, either positive common or negative common can be used.				Negative common

### **Specified Layout**

A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 20 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.



## Plug-in Connector Connecting Base


Lead Wire

# JSY1000/3000/5000 Series (€ ₽४ ज्लाड)

Internal Pilot

Type 10 Side Ported

How to Order Manifolds



62		ø2	•	_	_	12
C4		ø4	۲	-	-	
C6 C8	Ę	ø6	•	•	_	
C8	raight	ø8	-	•	_	
C10	l S	ø10	—	—	•	O.S.
C12		ø12	—	_	•	00
CM*1		Straight port, mixed sizes	۲	•	•	O Class
		port size uch fittings)	ø8	ø10	ø12	

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

 The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

#### DIN Rail Option

shown below.)

mounting type manifold.

Nil	DIN rail mounting (With DIN rail)								
0	DIN rail	DIN rail mounting (Without DIN rail)							
3	For 3 stations	Creatify a length langer than							
:	:	Specify a length longer than that of the standard rail.							
24	For 24 stations	that of the standard rail.							


the number of valve stations. (Refer to "DIN Rail Option"

Refer to page 160 for details on securing the DIN rail


### How to Order Manifold Assembly

power-saving circuit specification

is available.








\* These figures show the "JJ5SY1-10L1□-05D-C4."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	ension	IS												r	1: Stations
_ _	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	107.5	114	120.5	127	133.5	140	146.5	153	159.5	166	172.5	179	185.5	192	198.5
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223
L4	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5
L5	14	17	14	17	13.5	16.5	13.5	16.5	13	16	13	16	12.5	15.5	12.5
L n	17	18	19	20	21	22	23	24							
L1	205	211.5	218	224.5	231	237.5	244	250.5							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	235.5	235.5	248	248	260.5	273	273	285.5							
L4	225	225	237.5	237.5	250	262.5	262.5	275							
L5	15.5	12	15	12	15	18	14.5	17.5							
78							Ø\$	SMC							




∗ These figures show the "JJ5SY1-10L1□-05D-C6."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	ension	IS												r	n: Stations
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	112.5	121.5	130.5	139.5	148.5	157.5	166.5	175.5	184.5	193.5	202.5	211.5	220.5	229.5	238.5
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	148	148	160.5	173	173	185.5	198	210.5	210.5	223	235.5	235.5	248	260.5	273
L4	137.5	137.5	150	162.5	162.5	175	187.5	200	200	212.5	225	225	237.5	250	262.5
L5	18	13.5	15	17	12.5	14	16	17.5	13	15	16.5	12	14	15.5	17.5
L n	17	18	19	20	21	22	23	24							
L1	247.5	256.5	265.5	274.5	283.5	292.5	301.5	310.5							
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4							
L3	273	285.5	298	298	310.5	323	335.5	335.5							
L4	262.5	275	287.5	287.5	300	312.5	325	325							
L5	13	14.5	16.5	12	13.5	15.5	17	12.5							
							_								70


**SMC** 



\* These figures show the "JJ5SY3-10L1 -05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.


L: Dim	ension	IS												r	1: Stations
/_ /_	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	115.1	126.6	138.1	149.6	161.1	172.6	184.1	195.6	207.1	218.6	230.1	241.6	253.1	264.6	276.1
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	148	160.5	173	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5
L4	137.5	150	162.5	162.5	175	187.5	200	212.5	225	237.5	250	262.5	275	287.5	300
L5	16.5	17	17.5	11.5	12	12.5	13	13.5	14	14.5	15	15.5	16	16.5	17
n	17	18	19	20	21	22	23	24							
	287.6	299.1	310.6	322.1	333.6	345.1	356.6	368.1							
L2	287.6 238.6	299.1 250.1	310.6 261.6	322.1 273.1	333.6 284.6	345.1 296.1	356.6 307.6	368.1 319.1							
L2 L3															
	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1							
L3	238.6 323	250.1 323	261.6 335.5	273.1 348	284.6 360.5	296.1 373	307.6 385.5	319.1 398							



\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	IS												r	: Stations
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	134.5	150.5	166.5	182.5	198.5	214.5	230.5	246.5	262.5	278.5	294.5	310.5	326.5	342.5	358.5
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	173	185.5	198	210.5	235.5	248	260.5	285.5	298	310.5	323	348	360.5	373	398
L4	162.5	175	187.5	200	225	237.5	250	275	287.5	300	312.5	337.5	350	362.5	387.5
L5	19.5	17.5	16	14	18.5	17	15	19.5	18	16	14.5	19	17	15.5	20
$\sum n$	17	18	10	20	21	22	23	04							
L //	17	10	19	20	21	22	23	24							
L1	374.5	390.5	406.5	422.5	438.5	454.5	470.5	486.5							
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5							
L3	410.5	423	435.5	460.5	473	485.5	510.5	523							
L4	400	412.5	425	450	462.5	475	500	512.5							
L5	18	16.5	14.5	19	17.5	15.5	20	18.5							
							6	SMC							81

#### **Electrical Wiring Specifications**



 For negative common specification, a valve for negative common or a valve without polarity should be used.

#### **Specified Layout**


A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 32 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.

#### Electrical characteristics

Item	Property
Conductor resistance Ω/km, 20°C	143 or less
Voltage limit V, 1 minute, AC	2000
Insulation resistance MΩ/km, 20°C	10 or more

Cannot be used for movable wiring The minimum bending radius of the cable is 55 mm.

#### **Electrical Wiring Specifications**



# Plug-in Connector Connecting Base $C \in L$


### EX600

# JSY1000/3000/5000 Series

Internal Pilot

Type 10 Side Ported

How to Order Manifolds



#### Series

1	JSY1000
3	JSY3000
5	JSY5000

le ported

### 2 Type

10	Sid

#### 🕄 SI unit

0	Without SI unit						
Q	DeviceNet <sup>®</sup>						
N	PROFIBUS DP						
V CC-Link							
EA	EtherNet/IP™						
EB	EtherNet/IP™ (IO-Link unit)						
DA EtherCAT (IO-Link unit)							
F	PROFINET						
FA	PROFINET (IO-Link unit)						
WE	EtherNet/IP <sup>™</sup> compatible wireless base*1						
WF	PROFINET compatible wireless base*1						
WS	Wireless remote*1						

- \*1 The wireless system is suitable for use only in a country where it is in accordance with the Radio Act and regulations of that country.
- I/O unit cannot be mounted without SI unit.
   Valve plate which connects manifold and SI unit is
- Valve plate which connects manifold and St unit is included, but it is not mounted to a valve without SI unit.
   For mounting, refer to the EX600 series on page 129.

#### SI unit output polarity, End plate type (Part no.

End pla	ate type	e (Fait	110.)	
SI unit output	M12 power supply	7/8 inch		pply connector A-coded
polarity	connector B-coded (EX600-ED2)	power supply connector (EX600-ED3)	Pin arrangement 1 (EX600-ED4)	Pin arrangement 2 (EX600-ED5)
Without SI unit		N	il	
SI unit positive common	2	3	6	8
SI unit negative common	4	5	7	9

 Ensure a match with the common specification of the valve to be used.

 When not selecting an SI unit, the symbol will be "nil."

### 5 I/O unit stations

Nil	None
1	1 station
:	:
9	9 stations

- \* When not selecting an SI unit, the symbol will be "nil."
- \* SI unit is not included in I/O unit stations.
- When I/O unit is selected, it is shipped separately, and assembled by users. Refer to the attached operation manual for mounting.

### P, E port entry, SUP/EXH block assembly

P, E port entry	Internal pilot	Internal pilot, Built-in silencer
U side (2 to 10 stations)	U	C
D side (2 to 10 stations)	D	E
Both sides (2 to 24 stations)	В	F


\* The 3/5(E) port is plugged for the built-in silencer type.

- \* When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- \* The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

#### 8 A, B port size (Metric/One-touch fitting)

Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	۲	-	-	122
C4		ø4	۲	_	-	
C6	Ē	ø6	•	•	_	
C8	Straight	ø8	—	•	-	
C10	l di	ø10	—	_	•	
C12		ø12	_	_	•	00
CM*1	1	Straight port, mixed sizes	۲	•	•	-O-Cher
		port size uch fittings)	ø8	ø10	ø12	

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM." \* The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.




Made to Order

vlade to

Order

RoHS



- \*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- This also includes the number of blanking plates.

### 9 Mounting and Option

Symbol	Mounting
Nil	Direct mounting
D	DIN rail mounting

- Enter the number of stations inside 
   when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.

#### **DIN Rail Option**


Nil	DIN rail n	nounting (With DIN rail)									
0	DIN rail n	nounting (Without DIN rail)									
3	For 3 stations	Cresify a length langer than									
		Specify a length longer that that of the standard rail.									
24	For 24 stations	ns Inat of the standard rall.									

 If the DIN rail must be mounted without an SI unit, select D0. Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

For details on the EX600 Integrated Type (For Input/Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to pages 129 and 130. (IP40 specifications may be required according to the I/O unit to be selected.) Please download the Operation Manual via the SMC website, https://www.smcworld.com



### How to Order Manifold Assembly



**∧** Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156.


For the JSY1000 series, only the power-saving circuit specification is available.

Symbol	With light	Surge voltage suppressor	Common specification
U			Non-polar
Z	•	•	Positive common
NZ			Negative common

- Select "U" or "Z" for the valve when the SI unit output polarity is positive common. Select "U" or "NZ" for the valve when the SI unit output polarity is negative common. Only "Z" and "NZ" types are available for the
- JSY1000 series.

When ordering a valve individually, the base gasket is not included. Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.






n1: Valve stations n2: I/O unit stations

### L3: DIN Rail Overall Length

Valve stations (n1) 1/0 2 3 Δ 5 7 8 9 10 11 12 13 14 15 16 18 19 20 21 22 23 24 6 17 unit stations (n2 185.5 185.5 198 198 210.5 210.5 223 235.5 235.5 248 248 260.5 260.5 273 285.5 298 298 310 5 310 5 323 323 0 235.5 235.5 248 285.5 285.5 298 260.5 260.5 273 273 298 310.5 310.5 323 323 335.5 335.5 348 348 360.5 360.5 373 1 2 285.5 298 310.5 310.5 348 410.5 410.5 423 273 285.5 298 323 323 335.5 335.5 348 360.5 360.5 373 385.5 385.5 398 398 335.5 348 348 360 5 360 5 385 5 385 5 398 410.5 435 5 435 5 448 460.5 460.5 3 323 323 373 373 398 410 5 423 423 448 4 373 385.5 385.5 398 398 410.5 410.5 423 423 435.5 435.5 448 448 460.5 473 473 485.5 485.5 498 498 510.5 5 410 5 423 435 5 435 5 448 448 460 5 460 5 473 473 485.5 485.5 498 498 510.5 510.5 523 523 535.5 535.5 548 548 560.5 6 460.5 473 473 485.5 485.5 498 498 510.5 510.5 523 523 535.5 535.5 548 560.5 560.5 573 573 585.5 585.5 598 598 610.5 7 510.5 523 523 535.5 535.5 548 548 560.5 560.5 573 573 585.5 585.5 598 598 610.5 610.5 623 623 635.5 635.5 648 648 8 560.5 560.5 573 573 585.5 585.5 598 598 610.5 610.5 623 623 635.5 648 648 660.5 660.5 673 685.5 685.5 698 698 673 q 610.5 610.5 623 623 635.5 635.5 648 648 660.5 660.5 673 673 685.5 685.5 698 698 710.5 710.5 723 723 735.5 735.5 748






n2: I/O unit stations

#### L3: DIN Rail Overall Length

Valve stations I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	210.5	223	235.5	235.5	248	260.5	273	273	285.5	298	298	310.5	323	335.5	335.5	348	360.5	360.5	373	385.5
1	235.5	248	248	260.5	273	273	285.5	298	310.5	310.5	323	335.5	335.5	348	360.5	373	373	385.5	398	410.5	410.5	423	435.5
2	285.5	285.5	298	310.5	310.5	323	335.5	348	348	360.5	373	385.5	385.5	398	410.5	410.5	423	435.5	448	448	460.5	473	473
3	323	335.5	348	360.5	360.5	373	385.5	385.5	398	410.5	423	423	435.5	448	448	460.5	473	485.5	485.5	498	510.5	510.5	523
4	373	385.5	398	398	410.5	423	423	435.5	448	460.5	460.5	473	485.5	485.5	498	510.5	523	523	535.5	548	560.5	560.5	573
5	423	435.5	435.5	448	460.5	460.5	473	485.5	498	498	510.5	523	535.5	535.5	548	560.5	560.5	573	585.5	598	598	610.5	623
6	473	473	485.5	498	510.5	510.5	523	535.5	535.5	548	560.5	573	573	585.5	598	598	610.5	623	635.5	635.5	648	660.5	660.5
7	510.5	523	535.5	548	548	560.5	573	573	585.5	598	610.5	610.5	623	635.5	635.5	648	660.5	673	673	685.5	698	710.5	710.5
8	560.5	573	585.5	585.5	598	610.5	610.5	623	635.5	648	648	660.5	673	685.5	685.5	698	710.5	710.5	723	735.5	748	748	760.5
9	610.5	623	623	635.5	648	660.5	660.5	673	685.5	685.5	698	710.5	723	723	735.5	748	748	760.5	773	785.5	785.5	798	810.5



\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

n1: Valve stations


n2: I/O unit stations

#### L3: DIN Rail Overall Length

Valve stations I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5
1	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5
2	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5
3	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473	473	485.5
4	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473	473	485.5	485.5	498	498	510.5	510.5	523	523
5	435.5	435.5	448	448	460.5	460.5	473	473	485.5	485.5	498	510.5	510.5	523	523	535.5	535.5	548	548	560.5	560.5	573	573
6	485.5	485.5	498	498	510.5	510.5	523	523	535.5	535.5	548	548	560.5	560.5	573	573	585.5	585.5	598	598	610.5	610.5	623
7	523	535.5	535.5	548	548	560.5	560.5	573	573	585.5	598	598	610.5	610.5	623	623	635.5	635.5	648	648	660.5	660.5	673
8	573	585.5	585.5	598	598	610.5	610.5	623	623	635.5	635.5	648	648	660.5	660.5	673	673	685.5	685.5	698	698	710.5	723
9	623	623	635.5	635.5	648	648	660.5	660.5	673	685.5	685.5	698	698	710.5	710.5	723	723	735.5	735.5	748	748	760.5	760.5

**SMC** 






n1: Valve stations

n2: I/O unit stations

### L3: DIN Rail Overall Length

Valve stations I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	198	210.5	223	235.5	235.5	248	260.5	260.5	273	285.5	298	298	310.5	323	323	335.5	348	360.5	360.5	373	385.5	398	398
1	248	260.5	273	273	285.5	298	298	310.5	323	335.5	335.5	348	360.5	373	373	385.5	398	398	410.5	423	435.5	435.5	448
2	298	310.5	310.5	323	335.5	348	348	360.5	373	373	385.5	398	410.5	410.5	423	435.5	435.5	448	460.5	473	473	485.5	498
3	348	348	360.5	373	385.5	385.5	398	410.5	410.5	423	435.5	448	448	460.5	473	473	485.5	498	510.5	510.5	523	535.5	548
4	385.5	398	410.5	423	423	435.5	448	448	460.5	473	485.5	485.5	498	510.5	523	523	535.5	548	548	560.5	573	585.5	585.5
5	435.5	448	460.5	460.5	473	485.5	498	498	510.5	523	523	535.5	548	560.5	560.5	573	585.5	585.5	598	610.5	623	623	635.5
6	485.5	498	498	510.5	523	535.5	535.5	548	560.5	560.5	573	585.5	598	598	610.5	623	623	635.5	648	660.5	660.5	673	685.5
7	535.5	535.5	548	560.5	573	573	585.5	598	598	610.5	623	635.5	635.5	648	660.5	673	673	685.5	698	698	710.5	723	735.5
8	573	585.5	598	610.5	610.5	623	635.5	648	648	660.5	673	673	685.5	698	710.5	710.5	723	735.5	735.5	748	760.5	773	773
9	623	635.5	648	648	660.5	673	685.5	685.5	698	710.5	710.5	723	735.5	748	748	760.5	773	773	785.5	798	810.5	810.5	823




n2: I/O unit stations

#### L3: DIN Rail Overall Length


Valve stations I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448
1	235.5	248	260.5	273	285.5	298	310.5	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	460.5	473	485.5
2	285.5	298	310.5	323	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	473	485.5	498	510.5	523	535.5
3	335.5	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	485.5	498	510.5	523	535.5	548	560.5	573	585.5
4	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5
5	423	435.5	448	460.5	473	485.5	498	510.5	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	648	660.5	673
6	473	485.5	498	510.5	523	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	660.5	660.5	673	685.5	698	710.5	723
7	523	535.5	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	660.5	673	673	685.5	698	710.5	723	735.5	748	760.5	773
8	560.5	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	823
9	610.5	623	635.5	648	660.5	673	685.5	698	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	823	835.5	848	848	860.5

**SMC** 



#### L3: DIN Rail Overall Length

Valve stations I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	223	235.5	248	260.5	273	285.5	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	423	435.5	448	460.5	473
1	273	285.5	298	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	435.5	448	460.5	473	485.5	498	510.5	523
2	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573
3	360.5	373	385.5	398	410.5	423	435.5	448	460.5	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	610.5
4	410.5	423	435.5	448	460.5	473	473	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	623	635.5	648	660.5
5	460.5	473	485.5	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	635.5	648	660.5	673	685.5	698	710.5
6	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5
7	548	560.5	573	585.5	598	610.5	623	635.5	648	660.5	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	798
8	598	610.5	623	635.5	648	660.5	673	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	810.5	823	835.5	848
9	648	660.5	673	685.5	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	823	823	835.5	848	860.5	873	885.5	898




#### L3: DIN Rail Overall Length

Valve stations I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	210.5	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5
1	260.5	273	285.5	298	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573	585.5	610.5
2	298	323	335.5	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	660.5
3	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	535.5	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698
4	398	410.5	423	448	460.5	473	498	510.5	523	535.5	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698	710.5	735.5	748
5	448	460.5	473	485.5	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	673	685.5	698	710.5	735.5	748	760.5	785.5	798
6	485.5	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	660.5	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	848
7	535.5	548	573	585.5	598	623	635.5	648	660.5	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5
8	585.5	598	610.5	635.5	648	660.5	685.5	698	710.5	723	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5	910.5	923	935.5
9	635.5	648	660.5	685.5	698	710.5	723	748	760.5	773	785.5	810.5	823	835.5	860.5	873	885.5	898	923	935.5	948	973	985.5

**SMC** 

# Connector Connecting Base JSY1000/3000/5000 Series



Valve stations (n1) unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5	398	423	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573
1	273	285.5	298	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573	598	610.5	623
2	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	660.5	673
3	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698	723
4	410.5	423	448	460.5	473	498	510.5	523	535.5	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698	723	735.5	748	760.5
5	460.5	473	498	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	673	685.5	698	710.5	735.5	748	760.5	785.5	798	810.5
6	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	673	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	848	860.5
7	548	573	585.5	598	623	635.5	648	660.5	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	848	860.5	873	885.5	910.5
8	598	623	635.5	648	660.5	685.5	698	710.5	723	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5	910.5	923	935.5	948
9	648	660.5	685.5	698	710.5	723	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5	898	923	935.5	948	973	985.5	—


# Plug-in Connector Connecting Base

Type 10/ Side Ported

# **JSY3000/5000** Series

# JJ5SY 3-10S AAN **C**6 9 Δ

EX245



1 Serie	es
3	JSY3000
5	JSY5000
2 Туре	<b>A</b>

🖉 Туј	De
10	Side ported

4 With or without I/O modules

Without I/O module

With I/O module When not selecting an SI unit, the symbol will

## SI unit

Symbol (Output polarity)	Protocol	Communication	Communication		
Negative common (PNP)		connector	connector specifications		
0		Without SI unit			
AAN		Push/Pull (SCRJ): 2 pcs.	Push/Pull (24 V): 2 pcs.		
ABN	PROFINET	Push/Pull (RJ45): 2 pcs.	Push/Pull (24 V): 2 pcs.		
ACN		M12: 2 pcs.	7/8 inch: 2 pcs.		

The valve output polarity for the SI unit is negative common (PNP).

## 5 Number of I/O modules

Nil	Without I/O module
1	1 station
:	:
8	8 stations

How to Order Manifolds

When not selecting an SI unit, the symbol will he "nil "

# P. E port entry

Nil

v

be "nil "

• • • •	• • ; = p • • • • • • ;						
U	U side (2 to 10 stations)						
D	D side (2 to 10 stations)						
В	Both sides (2 to 24 stations)						

# 8 SUP/EXH block assembly

Nil	Internal pilot
S	Internal pilot, Built-in silencer

- \* The 3/5(E) port is plugged for the built-in silencer type.
- \* When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

## G Valve stations

• · · ·	ve otatioi	
Symbol	Stations	Note
02	2 stations	
:	:	Double wiring*1
16	16 stations	
02	2 stations	Specified layout*2
:	:	(Available up to 32
24	24 stations	solenoids)

- \*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout
- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet.

(Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)

\* This also includes the number of the blanking plate assembly.

## 9 A. B port size (Metric)

Symbol		A, B port	JSY3000	JSY5000	~
C6		ø6 One-touch fitting		_	
C8	Ħ	ø8 One-touch fitting		_	
C10	raig	ø10 One-touch fitting	-	•	
C12	ţ	ø12 One-touch fitting	-	•	
<b>CM</b> *1		Straight port, mixed sizes		•	08
P	P, E port size (One-touch fittings)		ø10	ø12	


\*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

For details on the EX245 Integrated Type (For Input/Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 131. Please download the Operation Manual via the SMC website, https:// www.smcworld.com

**≥SMC** 

# Element Connector Connecting Base JSY3000/5000 Series

# How to Order Manifold Assembly



Sei	ries
3	JSY3000
5	JSY5000
5	JSY5000

8 Pile	ot valve exhaust method
0	Pilot valve individual exhaust

Rated voltage
 24 VDC


🕑 ту	be of a	actuation
------	---------	-----------

1	0 position	Single					
2	2-position	Double					
3		Closed center					
4	3-position	Exhaust center					
5		Pressure center					
Α	4	N.C./N.C.					
В	4-position dual 3-port	N.O./N.O.					
С	uua 3-port	N.C./N.O.					

**5** Light/surge voltage suppressor and common specification

Sy	mbol	With light	Surge voltage suppressor	Common specification		
	U	•		Non-polar		
	NZ	•	•	Negative common		


6)	Man	ual	ove	rride




When ordering a valve individually, the base gasket is not included. Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.

# **▲**Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156.



# JSY3000/5000 Series




* The I 1 dimension is the din	pension without an I/O module	Add 54 mm to this dimension for	r each I/O module

Dimensio	ons	<b>S</b> * n2 is the number of I/O module stations.																					
Valve stations n1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	191.2	202.7	214.2	225.7	237.2	248.7	260.2	271.7	283.2	294.7	306.2	317.7	329.2	340.7	352.2	363.7	375.2	386.7	398.2	409.7	421.2	432.7	444.2
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
~~																							

**SMC** 

# Connector Connecting Base JSY3000/5000 Series



Dimensio	ons	*	n2 is t	he nur	nber o	t I/O m	nodule	statio	ns.														
Valve stations n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	210.6	226.6	242.6	258.6	274.6	290.6	306.6	322.6	338.6	354.6	370.6	386.6	402.6	418.6	434.6	450.6	466.6	482.6	498.6	514.6	530.6	546.6	562.6
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5

# Plug-in Connector Connecting Base


EX250

# JSY1000/3000/5000 Series

Internal Pilot

Type 10 Side Ported

# How to Order Manifolds



Ē

## Series

1	JSY1000
3	JSY3000
5	JSY5000

## SI unit

0	Without SI unit								
Q	DeviceNet	DeviceNet <sup>™</sup> (Negative common)							
TA		2 isolated	8 in/8 out						
TB	AS-Interface	common type	4 in/4 out						
TC	(Negative common)	1 common	8 in/8 out						
TD	commony	type	4 in/4 out						
ZE	EtherNet/IP™ (Negative common)								

 Ensure a match with the common specification of the valve to be used.

Input block cannot be mounted without SI unit.

 The supply current from the SI unit of AS-Interface applicable 1 power supply system specification to the input block and valve is limited.

Этур	e
10	Side ported

## 4 Input block stations

Nil	None
1	1 station
:	
8	8 stations

\* When not selecting an SI unit, the symbol will be "nil." The maximum number of stations is limited for the AS-Interface applicable SI unit.

# 5 Input block type

	PNP sensor input	NPN sensor input				
Without input block	Nil					
M12, 2 inputs	Α	D				
M12, 4 inputs	B	E				
M8, 4 inputs	С	F				

\* When not selecting an SI unit, the symbol will be "nil."

## P, E port entry, SUP/EXH block assembly

P, E port entry	Internal pilot	Internal pilot, Built-in silencer		
U side (2 to 10 stations)	U	C		
D side (2 to 10 stations)	D	E		
Both sides (2 to 24 stations)	В	F		

\* The 3/5(E) port is plugged for the built-in silencer type.

\* When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
\* The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

A, B port size (Metric/One-touch fitting) JSY1000 JSY3000 JSY5000 Symbol A, B port C2 ø2 . C4 ø4 . C6 \_\_\_\_\_t ø6 . . Ø8 • **C8** Strai C10 ø10 . C12 ø12 . CM\*1 . . Straight port, mixed sizes . P, E port size ø8 ø10 ø12 (One-touch fittings)

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM,"
\* The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

For details on the EX250 Integrated Type (For Input/Output) Serial Transmission System, refer to the **Web Catalog** and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 133. Please download the Operation Manual via the SMC website, https://www.smcworld.com

Made Ord		ade to Order efer to page 156 for details.)									
		Specification									
E:	xternal	pilot (SUP/EXH block assembly)									
_	Valve stations										
-1		Note									
02	2 stations										
02	2 stations										
:	2 stations :	Double wiring*1									
: 16	2 stations : 16 stations	Double wiring*1									
:	:										
: 16	: 16 stations	Double wiring*1 Specified layout*2 (Up to 32 solenoids available)									

- \*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this not desired, order with a specified layout.
- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.) When determining the number of valve stations, note that the maximum number of solenoids for the AS-Interface applicable SI unit specification is as follows.

8 in/8 out specification: Max. 8 solenoids
 4 in/4 out specification: Max. 4 solenoids

- This also includes the number of blanking plates.
- \* For the product without the SI unit (S0), note the maximum number of solenoids of the SI unit that will be mounted. If the layout is specified, indicate it on the manifold specification sheet.

## 9 Mounting and Option

Symbol	Mounting
Nil	Direct mounting
D	DIN rail mounting

- \* Enter the number of stations inside □ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.
- \* DIN rail mounting (D□) is not available for the product without the SI unit (S0).

## DIN Rail Option


Nil         DIN rail mounting (With DIN rail)           0         DIN rail mounting (Without DIN rail)           3         For 3 stations	
3 For 3 stations	Nil
3 For 3 stations	0
	3
Specify a length longer than that of the standard rail.	:
24 For 24 stations	24

 Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)



embly

# How to Order Manifold Assembly



# **▲**Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156.

For the JSY1000 series, only the power-saving circuit specification is available.


# **SMC**

Since the base gasket is attached to the manifold, please order the base gasket

separately if it is needed for maintenance.

Refer to page 137 for base gasket and

mounting screw part numbers.



n1: Number of valve stations of the JSY1000 n2: Input block stations

and silencer.


\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

# L3: DIN Rail Overall Length

Valve station (n1 vo unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	298	298	310.5	310.5	323	323
1	198	210.5	210.5	223	223	235.5	235.5	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348
2	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5
3	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	348	348	360.5	360.5	373	373	385.5	385.5
4	260.5	273	273	285.5	285.5	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5
5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	435.5
6	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448
7	323	335.5	335.5	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473
8	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473	485.5	485.5	498
6 7 8	323	335.5	335.5	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	46	i0.5

**SMC** 

# Connector Connecting Base JSY1000/3000/5000 Series




L1 = 9 x n1 + 139 + 21 x n2 L2 = 9 x n1 + 43.4 L4 = L3 - 10.5 L5 = (L3 - L1) / 2L6 = 21 x n2 + 83.8

\* These figures show the "JJ5SY1-10SQ1A-05D-C6."

- \* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- \* When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

n1: Number of valve stations of the JSY1000 n2: Input block stations

1 210.5 210.5 223 235.5 248 248 260.5 273 285.5 285.5 298 310.5 310.5 323 335.5 348 348 360.5 373 373 385.5 398 4	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	9	8	7	6	5	4	3		Valve stations I/O unit stations (n2)
<b>2</b> 223 235.5 248 260.5 260.5 273 285.5 285.5 285 310.5 323 323 335.5 348 360.5 360.5 373 385.5 385.5 398 410.5 423 4	85.5	373	360.5	360.5	348	335.5	335.5	323	310.5	298	298	285.5	273	273	260.5	248	235.5	235.5	223	210.5	210.5	198	185.5	0
	10.5	398	385.5	373	373	360.5	348	348	335.5	323	310.5	310.5	298	285.5	285.5	273	260.5	248	248	235.5	223	210.5	210.5	1
<b>3</b> 248 260.5 273 273 285.5 298 298 310.5 323 335.5 335.5 348 360.5 360.5 373 385.5 398 398 410.5 423 435.5	23	423	410.5	398	385.5	385.5	373	360.5	360.5	348	335.5	323	323	310.5	298	285.5	285.5	273	260.5	260.5	248	235.5	223	2
	48	435.5	435.5	423	410.5	398	398	385.5	373	360.5	360.5	348	335.5	335.5	323	310.5	298	298	285.5	273	273	260.5	248	3
<b>4</b> 273 285.5 285.5 298 310.5 310.5 310.5 323 335.5 348 348 360.5 373 373 385.5 398 410.5 410.5 423 435.5 435.5 448 460.5 4	73	460.5	448	435.5	435.5	423	410.5	410.5	398	385.5	373	373	360.5	348	348	335.5	323	310.5	310.5	298	285.5	285.5	273	4
5 285.5 298 310.5 323 323 335.5 348 360.5 360.5 373 385.5 388 410.5 423 423 435.5 448 448 460.5 473 485.5 485 485 485 485 485 485 485 485 485 48	85.5	485.5	473	460.5	448	448	435.5	423	423	410.5	398	385.5	385.5	373	360.5	360.5	348	335.5	323	323	310.5	298	285.5	5
6 310.5 323 335.5 335.5 348 360.5 360.5 373 385.5 398 398 410.5 423 435.5 435.5 448 460.5 460.5 473 485.5 498 498 5	10.5	498	498	485.5	473	460.5	460.5	448	435.5	435.5	423	410.5	398	398	385.5	373	360.5	360.5	348	335.5	335.5	323	310.5	6
<b>7</b> 335.5 348 348 360.5 373 373 385.5 398 410.5 410.5 423 435.5 438 460.5 473 473 485.5 498 510.5 510.5 523 5	35.5	523	510.5	510.5	498	485.5	473	473	460.5	448	435.5	435.5	423	410.5	410.5	398	385.5	373	373	360.5	348	348	335.5	7
<b>8</b> 360.5 360.5 373 385.5 385.5 398 410.5 423 423 435.5 448 448 460.5 473 485.5 498 510.5 510.5 510.5 523 535.5 548 5	48	548	535.5	523	510.5	510.5	498	485.5	485.5	473	460.5	448	448	435.5	423	423	410.5	398	385.5	385.5	373	360.5	360.5	8



L4 = L3 - 10.5L5 = (L3 - L1) / 2

L6 = 21 x n 2 + 82


n1: Number of valve stations of the JSY3000 n2: Input block stations \* These figures show the "JJ5SY3-10SQ1A-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

Valve stations I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448
1	210.5	223	235.5	248	260.5	273	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	423	435.5	448	460.5
2	235.5	248	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	398	410.5	423	435.5	448	460.5	473	485.5
3	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5	373	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5
4	273	285.5	298	310.5	323	335.5	348	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	485.5	498	510.5	523
5	298	310.5	323	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	460.5	473	485.5	498	510.5	523	535.5	548
6	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573
7	335.5	348	360.5	373	385.5	398	410.5	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	560.5	573	585.5
8	360.5	373	385.5	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	535.5	548	560.5	573	585.5	598	610.5



# Connector Connecting Base JSY1000/3000/5000 Series



n1: Number of valve stations of the JSY5000 n2: Input block stations

\* These figures show the "JJ5SY5-10SQ1A-05D-C12."

\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

Valve stations I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	210.5	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5
1	235.5	248	260.5	273	298	310.5	323	335.5	360.5	373	385.5	410.5	423	435.5	448	473	485.5	498	523	535.5	548	560.5	585.5
2	248	260.5	285.5	298	310.5	335.5	348	360.5	373	398	410.5	423	448	460.5	473	485.5	510.5	523	535.5	560.5	573	585.5	598
3	273	285.5	298	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573	585.5	610.5	623
4	298	310.5	323	335.5	360.5	373	385.5	410.5	423	435.5	448	473	485.5	498	510.5	535.5	548	560.5	585.5	598	610.5	623	648
5	310.5	335.5	348	360.5	373	398	410.5	423	435.5	460.5	473	485.5	510.5	523	535.5	548	573	585.5	598	623	635.5	648	660.5
6	335.5	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	660.5	673	685.5
7	360.5	373	385.5	398	423	435.5	448	473	485.5	498	510.5	535.5	548	560.5	585.5	598	610.5	623	648	660.5	673	685.5	710.5
8	373	398	410.5	423	435.5	460.5	473	485.5	510.5	523	535.5	548	573	585.5	598	610.5	635.5	648	660.5	685.5	698	710.5	723

# Plug-in Connector Connecting Base

EX260

# **JSY1000/3000/5000** Series

Refer to page 106 for details on manifolds that support safety communication (PROFIsafe).

## Internal Pilot

Type 10 Side Ported

# How to Order Manifolds

Side ported

U side (2 to 10 stations) D side (2 to 10 stations)

Both sides (2 to 24 stations)


Internal pilot

Internal pilot, Built-in silencer The 3/5(E) port is plugged for the built-in

When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.

ordered as Made to Order. For details, refer

The external pilot specification should be



2 Type

D P, E port entry

6 SUP/EXH block assembly

10

U

D в

Nil

s

silencer type.

to page 156.

# 4

U Ser	les
1	JSY1000
3	JSY3000
5	JSY5000

#### SI unit (Output polarity, Protocol, Number of outputs, Communication connector)

	unication co	hineetor)		
Symbol (Out			Number	Communication
Positive common (NPN)	Negative common (PNP)	Protocol	of outputs	connector
0	*1	Without	SI unit	
QA	QAN	DeviceNet®	32	M12
QB	QBN	Devicemet	16	IVITZ
NA	NAN		32	M12
NB	NBN	PROFIBUS	16	10112
NC	NCN	DP	32	*3
ND	NDN	1	16	D-sub
VA	VAN	CC-Link	32	M12
VB	VBN	CC-LINK	16	IVITZ
DA	DAN	EtherCAT	32	M12
DB	DBN	EllierCAT	16	11/12
FA	FAN	PROFINET	32	M12
FB	FBN	PROFINEI	16	11/12
EA	EAN	EtherNet/IP™	32	M12
EB	EBN	Emenvel/IP ····	16	11/12
*2	GAN	Ethernet	32	M12
*2	GBN	POWERLINK	16	11/12
*2	KAN	IO-Link	32*4	M12

\*1 Without SI unit, the output polarity is decided by the SI unit used.

- Ensure a match with the common
- specification of the valves to be used. Positive common (NPN) type is not available.

\*3 IP40 for the D-sub applicable

communication connector specification \*4 Only the 32 outputs type is available

\* DIN rail cannot be mounted without SI unit.

## A, B port size (Metric/One-touch fitting)

#### Symbol A, B port JSY1000 JSY3000 JSY5000

C2		ø2	•	_	_	12
C4		ø4	۲	_	_	
C6	Ę	ø6	۲	•	-	
C8	aic	ø8	_	•	_	
C10	đ	ø10	_	_	•	O. C.
C12		ø12	—	_	•	00
<b>CM</b> *1		Straight port, mixed sizes	•	•	•	- Okane
			ø8	ø10	ø12	
	C12 CM*1 P	C6 C8 C10 C12 CM*1 P, E	C6         tipe         Ø6           C8         Ø8         Ø8           C10         Ø10         Ø12	C6         ₹         Ø6         ●           C10         0         08         -           C12         010         -         012           CM*1         Straight port, mixed sizes         ●           P, E port size         08         08	C6         ±         e6         ●           C8         e8          ●           C10         50         e10             C12         e12              CM*1         Straight part, mixed sizes         ●         ●            P, E port size         a9         a10	C6         ±         ∞6         ●         −           C8         ∞8         −         ●         −         −         −           C10         5         ∞10         −         −         ●         −         ●         −         ●         −         ●         −         ●         □         −         □         □         −         ●         ○         012         □         −         ●         ●         ●         ●         ○         012         □         −         ●         ●         ○         012         ○         □

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

\* The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

For details on the EX260 Integrated Type (For Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 134. Please download the Operation Manual via the SMC website, https://www.smcworld.com



### 4 Valve stations

In the	e case	of the 32-output SI unit
Symbol	Stations	Note
02	2 stations	
:	:	Double wiring*1
16	16 stations	
02	2 stations	0
:	:	Specified layout*2 (Up to 32 solenoids available)
24	24 stations	(Op to 32 solerious available)

#### In the case of the 16-output SI unit

		of the roouput of unit						
Symbol	Stations	Note						
02	2 stations							
:		Double wiring*1						
08	8 stations							
02	2 stations	0						
:		Specified layout*2 (Up to 16 solenoids available)						
16	16 stations	(Op to 16 soleriolds available)						

- \*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- \* This also includes the number of blanking plates
- For the product without the SI unit (S0), note the maximum number of solenoids of the SI unit that will be mounted. If the layout is specified, indicate it on the manifold specification sheet.

# 8 Mounting and Option

Symbol	Mounting
Nil	Direct mounting
D	DIN rail mounting


- ∗ Enter the number of stations inside □ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.
- DIN rail mounting (DD) is not available for the product without the SI unit (S0).

## **DIN Rail Option**

Nil	DIN rail mounting (With DIN rail)								
0	DIN rail mounting (Without DIN rail)								
3	For 3 stations								
:	:	Specify a length longer that that of the standard rail.							
24	For 24 stations	that of the standard fail.							

- \* Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)
- @SMC

# How to Order Manifold Assembly



If the JSY3000/S000 series is to be continuously energized, please be sure to select the powersaving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156. For the JSY1000 series, only the

For the JSY1000 series, only the power-saving circuit specification is available.

**SMC** 

\* Only "Z" and "NZ" types are available for the

JSY1000 series.

Protective class

class II (Mark: (1))

separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.

# Plug-in Connector Connecting Base



# ISY1000/3000/5000 Series

Safety Communication Protocol (PROFIsafe)

#### Using the safety communication protocol

Refer to the EX260 Web Catalog for details on units that support the safety communication protocol. When using a manifold valve within an ISO 13849-compliant safety system, the device needs to be considered from both the pneumatic circuit and the electric side

EX260


Devices (including valves) need to be selected based on whether their functions are in line with the safety level of the equipment as a whole.

The use of valves that have been validated as being compliant with ISO 13849-2 may be required. For details on valves that have been validated, please contact SMC

In addition, refer to "Safety Instructions" for precautions on model selection.

## Internal Pilot

How to Order Manifolds



Made to Order (Refer to page 156 for details.) Specification External pilot (SUP/EXH block assembly)

Communication connector)

lenative on

(PNP)

FPN

by the SI unit used Ensure a match with the common specification of the valves to be used.

Symbol (Output polarity)

**0**\*1

(NPN)

3 SI unit (Output polarity, Protocol, Number of outputs,

\*1 Without SI unit, the output polarity is decided

\*2 Positive common (NPN) type is not available. \*3 Only the 32 outputs type is available. \* DIN rail cannot be mounted without SI unit.

Protocol


Number

of

outputs

Without SI unit PROFIsafe 32\*3 M12

connector



### Series

1	JSY1000
3	JSY3000
5	JSY5000

# Valve stations

Symbol	Stations	Note					
02	2 stations						
:	:	Double wiring*1					
16	16 stations						
02	2 stations	0					
:	:	Specified layout*2 (Up to 32 solenoids available)					
24	24 stations	(Op to 32 soleholds available)					

\*1 Double wiring: 2-position single, 3-position, and 4-position valves can be used on all manifold stations

The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.

- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 3-position and 4-position valves cannot be used where single wiring has been specified.)
- This also includes the number of blanking plates

10

U	U side (2 to 10 stations)								
D	D side (2 to 10 stations)								
В	Both sides (2 to 24 stations)								

Side ported

## 6 SUP/EXH block assembly

Nil	Internal pilot								
S	Internal pilot, Built-in silencer								

- \* The 3/5(E) port is plugged for the built-in silencer type. \* When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

## A. B port size (Metric/One-touch fitting)

Symbol		A, B port	JSY1000	JSY3000	JSY5000	]			
C2		ø2	•	—	—	1			
C4		ø4	•	—	—				
C6	Ĕ	ø6	•	•	—				
C8	aig	ø8	_	•	—				
C10	5	ø10	_	—	•				
C12				[	ø12	—	—	•	00
CM*1		Straight port, mixed sizes	•	•	•	- Oktown			
P, E	por	t size (One-touch fittings)	ø8	ø10	ø12				

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

\* The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

### 8 Mounting and Option

S	/mbol	Mounting
	Nil	Direct mounting
	D	DIN rail mounting

- ∗ Enter the number of stations inside □ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.
- DIN rail mounting (DD) is not available for the product without the SI unit (S0).

#### **DIN Rail Option**

Nil	DIN rail mounting (With DIN rail)								
0	DIN rail	DIN rail mounting (Without DIN rail)							
3	For 3 stations								
:	:	Specify a length longer than that of the standard rail.							
24	For 24 stations								

Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)


For details on the EX260 Integrated Type (For Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 134. Please download the Operation Manual via the SMC website, https://www.smcworld.com



# Connector Connecting Base JSY1000/3000/5000 Series

# [Validated product examples]


Please contact SMC for further details as supported variations are continually being added.



U Ser	les
1	JSY1000
3	JSY3000
5	JSY5000

## B Pilot valve exhaust method

Pilot valve individual exhaust 0



#### 4-position N.O./N.O. в dual 3-port С N.C./N.O.

3-position

3 4

5

A

Closed center

Exhaust center

Pressure center N.C./N.C.

## **5** Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification		
U	•		Non-polar		
NZ	•	•	Negative common		

\* Only "NZ" type is available for the JSY1000 series.




\* When ordering a valve individually, the base gasket is not included. Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.

# ▲ Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the powersaving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156.

For the JSY1000 series, only the power-saving circuit specification is available.




\* These figures show the "JJ5SY1-10SQA-05D-C4."

 Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	L: Dimensions n: Stations														
L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	99.2	105.7	112.2	118.7	125.2	131.7	138.2	144.7	151.2	157.7	164.2	170.7	177.2	183.7	190.2
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	123	135.5	135.5	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L4	112.5	125	125	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L5	12	15	12	15	18	15	18	14	17	14	17	14	17	14	17
∖_ n	17	18	19	20	21	22	23	24							
L1	196.7	203.2	209.7	216.2	222.7	229.2	235.7	242.2							
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4							
L3	223	235.5	235.5	248	248	260.5	260.5	273							
L4	212.5	225	225	237.5	237.5	250	250	262.5							
L5	13	16	13	16	13	16	13	16							
108							Ø\$	SMC							

# Connector Connecting Base JSY1000/3000/5000 Series




\* These figures show the "JJ5SY1-10SQA-05D-C6."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dimensions n: Stati														1: Stations	
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	104.2	113.2	122.2	131.2	140.2	149.2	158.2	167.2	176.2	185.2	194.2	203.2	212.2	221.2	230.2
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	135.5	148	148	160.5	173	173	185.5	198	210.5	210.5	223	235.5	235.5	248	260.5
L4	125	137.5	137.5	150	162.5	162.5	175	187.5	200	200	212.5	225	225	237.5	250
L5	16	18	13	15	17	12	14	16	17	13	15	16	12	14	15
∕_ n	17	18	19	20	21	22	23	24							
		-													
_L1	239.2	248.2	257.2	266.2	275.2	248.2	293.2	302.2							
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4							
L3	273	273	285.5	298	310.5	310.5	323	335.5							
L4	262.5	262.5	275	287.5	300	300	312.5	325							
L5	17	13	14	16	18	13	15	17							
SVC															109




\* These figures show the "JJ5SY3-10SQA-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	: Dimensions n: Stations														
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	106.8	118.3	129.8	141.3	152.8	164.3	175.8	187.3	198.8	210.3	221.8	233.3	244.8	256.3	267.8
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	135.5	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	273	285.5	298
L4	125	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	262.5	275	287.5
L5	15	15	16	16	17	17	18	12	12	13	13	14	14	15	15
	4-	10	10												
L n	17	18	19	20	21	22	23	24							
L1	279.3	290.8	302.3	313.8	325.3	336.8	348.3	359.8							
L2	238.6	250.1	261.1	273.1	284.6	296.1	307.6	319.1							
L3	310.5	323	335.5	348	360.5	360.5	373	385.5							
L4	300	312.5	325	337.5	350	350	362.5	375							
L5	16	16	17	17	18	12	13	13							
110															

# Connector Connecting Base JSY1000/3000/5000 Series



\* These figures show the "JJ5SY5-10SQA-05D-C12." \* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	L: Dimensions n: Stations														
/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	126.2	142.2	158.2	174.2	190.2	206.2	222.2	238.2	254.2	270.2	286.2	302.2	318.2	334.2	350.2
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	185.5	198	223	235.5	248	273	285.5	298	310.5	335.5	348	360.5	385.5
L4	150	162.5	175	187.5	212.5	225	237.5	262.5	275	287.5	300	325	337.5	350	375
L5	17	16	14	12	17	15	13	18	16	14	12	17	15	13	18
_	. –														
L n	17	18	19	20	21	22	23	24							
L1	366.2	382.2	398.2	414.2	430.2	446.2	462.2	478.2							
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5							
L3	398	410.5	423	448	460.5	473	485.5	510.5							
L4	387.5	400	412.5	437.5	450	462.5	475	500							
L5	16	14	13	17	15	14	12	16							
© SVIC															111

# Plug-in Connector Connecting Base


EX120

# JSY1000/3000/5000 Series С Є ӋҞ понѕ

Internal Pilot

Type 10 Side Ported

How to Order Manifolds



## Series

• • • •	
1	JSY1000
3	JSY3000
5	JSY5000

# 🕄 SI unit

0	Without	t SI unit				
Q	DeviceNet® (Posit	ive common NPN)				
R1	OMRON CompoBus/S	16 outputs				
R2	(Positive common NPN)	8 outputs				
V	CC-Link (Positiv	e common NPN)				
<b>ZB</b> *1	CompoNet <sup>®</sup>	Positive common NPN				
ZBN*1	Componet	Negative common PNP				

- \*1 The communication connector (for the opposite side) is not provided. Please order it separately.
- \* Ensure a match with the common specification of the valve to be used.

(One-touch fittings)



# **9** P, E port entry

<u> </u>								
U	U side (2 to 10 stations)							
D	D side (2 to 10 stations)							
В	Both sides (2 to 16 stations)							

## 6 SUP/EXH block

Nil	Internal pilot
S	Internal pilot, Built-in silencer

- The 3/5(E) port is plugged for the built-in silencer type.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

Made to Order (Refer to page 156 for details.)											
Specification											
E	xternal	pilot (SUP/EXH block assembly)									
Valve stations											
Symbol	Stations	Note									
02	2 stations										
		Double wiring*1									
08	8 stations										
02	2 stations	Creatified lawsuit?									
		Specified layout*2 (Up to 16 solenoids available)									
16	16 stations	(op to to solenoids available)									
*1 D	ouble v	viring: 2-position single, double,									

- \*1 Double wirnig: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- \*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- \* This also includes the number of blanking plates.
- Since R2 type SI unit has 8 outputs, note that up to 8 solenoids can be accommodated.

• • • •	<b>۲</b>	011 3120 (100	uno/one-	touch nu	iiig)	
Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	•	—	-	12
C4	1	ø4	•	—	-	
C6	aight	ø6	•	•	-	
C8		ø8	—	•	-	
C10	l to	ø10	—	—	•	
C12	1	ø12	_	_	•	00
CM*1		Straight port, mixed sizes	•	•	•	- Ok Con
		port size	ø8	ø10	ø12	

# A, B port size (Metric/One-touch fitting)

\*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

 The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

# 8 Mounting and Option

Symbol	Mounting
Nil	Direct mounting
D	DIN rail mounting

- \* Enter the number of stations inside 
  when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.

#### **DIN Rail Option**


Nil	DIN ra	DIN rail mounting (With DIN rail)										
0	DIN rail	DIN rail mounting (Without DIN rail)										
3	For 3 stations											
:	:	Specify a length longer than that of the standard rail.										
16	For 16 stations	that of the standard rail.										

 If the DIN rail must be mounted without an SI unit, select D0. Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

For details on the EX120 Integrated Type (For Output) Serial Transmission System, refer to the **Web Catalog** and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 135. Please download the Operation Manual via the SMC website, https://www.smcworld.com



# How to Order Manifold Assembly






type) specification. Refer to "Made to Order" on page 156.

For the JSY1000 series, only the power-saving circuit specification is available.

@SMC



\* These figures show the "JJ5SY1-10S3V-05D-C4."


 Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dim	r: Station n: Statio														: Stations
 	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	104.3	110.8	117.3	123.8	130.3	136.8	143.3	149.8	156.3	162.8	169.3	175.8	182.3	188.8	195.3
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	135.5	148	148	160.5	160.5	173	173	185.5	198	198	210.5	210.5	223	223
L4	125	125	137.5	137.5	150	150	162.5	162.5	175	187.5	187.5	200	200	212.5	212.5
L5	16	12	15	12	15	12	15	12	15	18	14	17	14	17	14

**SMC** 

# Connector Connecting Base JSY1000/3000/5000 Series




\* These figures show the "JJ5SY1-10S3V-05D-C6."

\* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

\* When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	ension	IS												r	: Stations
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	109.3	118.3	127.3	136.3	145.3	154.3	163.3	172.3	181.3	190.3	199.3	208.3	217.3	226.3	235.3
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	135.5	148	160.5	160.5	173	185.5	198	198	210.5	223	223	235.5	248	260.5	260.5
L4	125	137.5	150	150	162.5	175	187.5	187.5	200	212.5	212.5	225	237.5	250	250
L5	13	15	17	12	14	16	17	13	15	16	12	14	15	17	13




\* These figures show the "JJ5SY3-10S3V-05D-C8."

\* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	IS												r	: Stations
L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	111.9	123.4	134.9	146.4	157.9	169.4	180.9	192.4	203.9	215.4	226.9	238.4	249.9	261.4	272.9
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5	298
L4	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275	287.5
L5	12	12	13	13	14	14	15	15	16	16	17	17	12	12	13
110															

**SMC** 

# Eligent Connector Connecting Base JSY1000/3000/5000 Series



\* These figures show the "JJ5SY5-10S3V-05D-C12."

\* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	IS												r	n: Stations
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	131.3	147.3	163.3	179.3	195.3	211.3	227.3	243.3	259.3	275.3	291.3	307.3	323.3	339.3	355.3
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	198	210.5	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5
L4	150	162.5	187.5	200	212.5	225	250	262.5	275	300	312.5	325	337.5	362.5	375
L5	15	13	17	16	14	12	17	15	13	18	16	14	12	17	15

# JSY1000/3000/5000 Series Common Dimensions


Dimensions: **JSY1000** Series


Type 10/Side Ported


External Pilot, Built-in Silencer


JJ5SY1-10 - Stations  $\overset{U}{\underset{C_6}{\mathbb{P}}}(S, R) - \overset{C_2}{\overset{C_2}{\underset{C_6}{\mathbb{P}}}}(D)$ 

## External pilot (Made to Order) P, E port entry: D









Calculation formula for L dimensions
L = 6.5 x n1 + 9 x n2 + 39.6

- n1: Number of 6.5 mm pitch manifold block stations (Applicable fitting: ø2, ø4)
- n2: Number of 9 mm pitch manifold block stations (Applicable fitting: ø6)
- \* These figures show the "JJ5SY1-10F2-05DR-C4."

# Common Dimensions JSY1000/3000/5000 Series


# Dimensions: **JSY3000** Series

Type **10/Side** Ported External Pilot, Built-in Silencer


# JJ5SY3-10 - Stations $\stackrel{U}{\stackrel{P}{_{R}}}$ (S, R) - $\stackrel{C_{S}^{6}}{_{C_{S}}}$ (D)


External pilot (Made to Order)

P, E port entry: D










\* These figures show the "JJ5SY3-10F2-05DR-C8."



# Dimensions: JSY5000 Series


Type 10/Side Ported


External Pilot, Built-in Silencer

# JJ5SY5-10 - Stations B(S, R) - C12(D)


External pilot (Made to Order)

P, E port entry: D







Calculation formula for L dimensions L = 16 x n + 41.5 n: Manifold stations



\* These figures show the "JJ5SY5-10F2-05DR-C12."



# Common Dimensions JSY1000/3000/5000 Series



- \* Refer to page 118 for dimensions of external pilot and built-in silencer.
- \* Refer to pages 86 to 89, 100, and 101 for dimensions when L6, b, and d are used for the calculation formula.
- \* Refer to pages below for dimensions that are not specified in each wiring specification.

D-sub connector (IP40/Connector entry direction adjustable)	: pp.	44, 45
D-sub connector (IP20/Compact type)	: pp.	50, 51
Flat ribbon cable (IP40/Connector entry direction adjustable)	: pp.	53, 54
Flat ribbon cable (IP20/Compact type)	: pp.	57, 58
Spring type terminal block box	: pp.	66, 67
Terminal block box	: pp.	70, 71
Lead wire	: pp.	78, 79
EX600	: pp.	86 to 89
EX250	: pp.	100, 101
EX260	: pp.	108, 109
EX120	: pp.	114, 115

#### Calculation formula for dimensions

L1 = 6.5 x n1 + 9 x n2 + a + b x n3
L2 = 6.5 x n1 + 9 x n2 + 43.4
M = {(L1 + c) / 12.5} + 1 Decimal fractions are truncated.
L3 = 12.5 x M + 23
L4 = L3 – 10.5
L5 = (L3 - L1 + c) / 2
L6 = b x n3 + d


Coefficient b с d а D-sub connector (IP20/Compact type) 64 1 61 \_ D-sub connector/Flat ribbon cable (IP40/Connector entry direction adjustable) 83 6.1 11.2 Flat ribbon cable (IP20/Compact type) 59.1 Spring type terminal block box 125.5 Terminal block box 146.8 Lead wire 94.5 Serial transmission: EX600 (M12 connector) 139 47 83.8 Serial transmission: EX600 (7/8 inch connector) 155.5 47 83.8 Serial transmission: EX250 139 21 83.8 Serial transmission: EX260 86.2 Serial transmission: EX120 91.3

n1: Number of 6.5 mm pitch manifold block stations (Applicable fittings: ø2, ø4) n2: Number of 9 mm pitch manifold block stations (Applicable fittings: ø6)


n3: Number of I/O units or input block stations

FW [D-sub connector (IP67)] is not available for the JSY1000.

# JSY1000/3000/5000 Series Type 10 Connector Connecting Base Manifold Exploded View




# Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series



The holding screw of the balance is ugneticated at the point (for the 35 1500).
 The clamp bracket fixing method for the JSY1000 is different depending on wiring. Refer to page 161.


# Manifold Parts Nos.




## 2 Clamp bracket

Series	Part no.
JSY1000	JSY11M-15P-1A
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A

# JSY3000/5000 Series



# Manifold Parts Nos.



	Pilot	type	<b>B</b>		
Symbol	Internal	External (Made to Order)	Built-in silencer		
Nil	۲	-	-		
S	•	-	•		
R	—	•	—		

 The 3/5(E) port is plugged for the built-in silencer type.

Symbol	P, E port	JSY3000	JSY5000
C10	ø10 One-touch fitting	•	-
C12	ø12 One-touch fitting	-	•
<b>00</b> *1	Plug	•	•

\*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S"

Not available for "R" type

#### SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY3000	JSY5000
(a) Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block


## 2 D-sub connector block <for IP67>

Part no.	Connector entry direction
SY30M-14-9A1	Upward
SY30M-14-9A2	Lateral

## **3 Clamp bracket**

Series	Part no.
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A


# Connector Connecting Base Manifold Exploded View JSY1000/3000 Series



The holding screw of the clamp bracket is tightened at one point (for the JSY3000) \* The clamp bracket fixing method for the JSY1000 is different depending on


wiring. Refer to page 161.

# Manifold Parts Nos.




2 Clamp bracket

Series	Part no.
JSY1000	JSY11M-15P-1A
JSY3000	SY30M-15-1A



# Manifold Parts Nos.



 The 3/5(E) port is plugged for the built-in silencer type.

# 2 Terminal block assembly

SY30M-130-1A

# SUP/EXH block assembly (D side) accessories and the number of accessories


Accessories	JSY1000 JSY3000	JSY5000
(a) Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block

### **3 Clamp bracket**


Series	Series Part no.	
JSY1000	JSY11M-15P-1A	
JSY3000	SY30M-15-1A	
JSY5000	SY50M-15-1A	

# туре 10 Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series



(Tightening torque: 1.4 N·m) (Tightening torque: 1.4 N·m)

# Manifold Parts Nos.



The 3/5(E) port is plugged for the built-in silencer type.

.

.

.

s

R

Symbol	P, E port	JSY1000	JSY3000	JSY5000
C8	ø8 One-touch fitting	•	—	—
C10	ø10 One-touch fitting	—	•	-
C12	ø12 One-touch fitting	_	_	•
<b>00</b> *1	Plug	•	•	•

\*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S"

Not available for "B" type

#### SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000
a Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block

## (4) Clamp bracket


Series	Part no.
JSY1000	JSY11M-15P-2A
JSY3000 SY30M-15-1A	
JSY5000	SY50M-15-1A

**3 Clamp bracket for terminal block box** 


(2) Terminal block box housing assembly

# SY30M-15-4A

VVQC1000-T0-1



# Manifold Parts Nos



#### SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000
a Tension bolt	None*1	3 pcs.

Part no.


JSY11M-15P-1A

SY30M-15-1A

SY50M-15-1A

\*1 Since the nuts are embedded in the SUP/EXH block

## ③ Clamp bracket



2 Lead wire connector block assembly

Symbol	Number of cores
1	34
2	17
3	9

Lead wire length [m]			
Symbol	Length		
1	0.6		
2	1.5		
3	3		


JSY3000 JSY5000

\* The part number is for 1 piece.


Series

JSY1000

## Type 10 Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series



## Manifold Parts Nos.



#### Pilot, Silencer type

	Pilot	Built-in	
Symbol	Internal (Made to Order)		silencer
Nil	•		—
S	۲	_	•
R	—	•	-

 The 3/5(E) port is plugged for the built-in silencer type.

#### Mounting

Symbol	Mounting	JSY1000	JSY3000	JSY5000
Nil	Direct mounting	•	•	•
D00	DIN rail mounting (Without DIN rail)	•	—	—
D0	DIN rail mounting (Without DIN rail)	—	•	•

#### P, E port size (One-touch fittings)

Symbol	P, E port	JSY1000	JSY3000	JSY5000
C8	ø8 One-touch fitting	•	—	_
C10	ø10 One-touch fitting	—	•	_
C12	ø12 One-touch fitting	—	_	•
<b>00</b> *1	Plug	•	•	•

\*1 Can be selected when the pilot, silencer type symbol is "Nii" or "S" Not available for "R" type


## SUP/EXH block assembly (D side)

accessories and the number of accessories

	Accessories	JSY1000/3000	JSY5000
(8	Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block

#### 2 Valve plate



 With mounting screws (2 pcs. of M4 x 6 and 2 pcs. of M3 x 8)

## Manifold Parts Nos.

## ③EX600 SI unit EX600-S

Communication protocol						
Symbol	Protocol	Output polarity				
PR1A	PROFIBUS DP	PNP (Negative common)				
PR2A	PROFIBUS DP	NPN (Positive common)				
DN1A	DeviceNet <sup>®</sup>	PNP (Negative common)				
DN2A	Devicemet	NPN (Positive common)				
MJ1	CC-Link	PNP (Negative common)				
MJ2	CC-LIIK	NPN (Positive common)				
EN3	EtherNet/IP™	PNP (Negative common)				
EN4	Ellernet/IF	NPN (Positive common)				
EN7	EtherNet/IP™	PNP (Negative common)				
EN8	(IO-Link unit)	NPN (Positive common)				
EC3	EtherCAT	PNP (Negative common)				
EC4	(IO-Link unit)	NPN (Positive common)				
PN1	PROFINET	PNP (Negative common)				
PN2	PROFINET	NPN (Positive common)				
PN3	PROFINET	PNP (Negative common)				
PN4	IO-Link unit	NPN (Positive common)				



## **3EX600 SI unit (Wireless compatible)**

# EX600-WEN 1

•	Output type				
Sy	mbol	Description			
	1	PNP (Negative common)			
	2	NPN (Positive common)			

#### Protocol

Symbol	SI unit type	Description
EN	Wireless base module	EtherNet/IP™ *1
PN	Wireless base module	PROFINET *1
SV	Wireless remote module	*1

\*1 The wireless system is suitable for use only in a country where it is in accordance with the Radio Act and regulations of that country.

## **④Clamp bracket**

Series	Part no.
For JSY1000	JSY11M-15P-2A
For JSY3000	SY30M-15-1A
For JSY5000	SY50M-15-1A

\* The part number is for 1 piece.

**⊘**SMC

## Manifold Parts Nos.

## 5 EX600 digital input unit

## EX600-DX P B Inpu

Symbol

t type		<ul> <li>Number of inputs, open-circuit detection, and connector</li> </ul>						
escription	1 1	Symbol Number of inputs Open-circuit detection Connector						
PNP	] [	В	8	No	M12 connector (5 pins) 4 pcs.			
NPN	] [	С	8	No	M8 connector (3 pins) 8 pcs.			
	· [	C1	8	Yes	M8 connector (3 pins) 8 pcs.			
	[	D	16	No	M12 connector (5 pins) 8 pcs.			
	[	E	16	No	D-sub connector (25 pins)			
	[	F	16	No	Spring type terminal block (32 pins)			

## 5 EX600 digital output unit

## EX600-DY P B Output type Symbol Descriptio

#### Number of outputs and connector

Symbol Number of outputs		Connector
<b>B</b> 8		M12 connector (5 pins) 4 pcs.
E 16		D-sub connector (25 pins)
F	16	Spring type terminal block (32 pins)

## 5 EX600 digital input/output unit

NPN



Symbol Description Р

N

#### Number of inputs/outputs and connector

n	Syr	mbol	Number of inputs	Number of outputs	Connector
٦		E	8	8	D-sub connector (25 pins)
		F	8	8	Spring type terminal block (32 pins)

## NPN 5 EX600 analog input/output unit

PNP



Ň

#### Number of input channels and connector

Symbol Number of input channels Connector M12 connector (5 pins) 2 pcs. 2 channels

## (5) EX600 analog input/output unit

Δ

## EX600-AMB

EX600-ED 2

connectors is different.

Connector

A-coded, Pin arrangement 1


	2			
Analog input/output	•Number of input/	output channel	s and connector	
	Symbol Number of input channels	Number of output channels	Connector	
	B 2 channels	2 channels	M12 connector (5 pins) 4 pcs.	
⑤ EX600 IO-Link u				
EX600-LA	<u>B</u> 1		<b>≜</b> Caution	
Port specification	•Number of ports a	Ind connector	The compatible SI unit models are	
Symbol Description	Symbol Number of ports	Connector	PROFINET compatible: EX600-SP	
A Port class A B Port class B		M12 connector (5 pins) 4 pcs.	EtherNet/IP™ compatible: EX600-SEC     EtherCAT compatible: EX600-SEC	
6 EX600 end plate				⑦ Clar



## ⑦Clamp bracket for EX600 EX600-ZMA3

Enclosed parts Round head screw with washer (M4 x 20) 1 pc. P-tight screw (4 x 14) 2 pcs.






Symbo 2 3

4


5







## туре 10 Connector Connecting Base Manifold Exploded View JSY3000/5000 Series



## Manifold Parts Nos.

## ①SUP/EXH block assembly

3 - • Se	<b>1 M — 1</b> <sup>ries</sup>	P –
3	JSY3000	
5	JSY5000	

#### Pilot, Silencer type

**1A** 

	Pilot type			
Symbol	Internal	External (Made to Order)	Built-in silencer	
Nil	۲	-	_	
S	٠	-	•	
R	—	•	—	
The O/E/E) port is plugged for the built in				

 The 3/5(E) port is plugged for the built-in silencer type.

## 2 EX245 SI unit



## P, E port size (One-touch fittings)

C10

Symbol	P, E port	JSY3000	JSY5000
C10	ø10 One-touch fitting	•	-
C12	ø12 One-touch fitting	_	•
<b>00</b> *1	Plug	•	•

\*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type

#### SUP/EXH block assembly (D side) accessories d the number of economics

and the number of accessories		
Accessories	JSY3000	JSY5000
(a) Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block

#### Connector type

Symbol	Communication connector	Power supply connector
1A	Push Pull connector (SCRJ): 2 pcs.	Push Pull connector (24 V): 2 pcs.
2A	Push Pull connector (RJ45): 2 pcs.	Push Pull connector (24 V): 2 pcs.
ЗA	M12 connector (4-pin, Socket, D-coded): 2 pcs.	7/8 inch connector (5-pin, Plug): 1 pc. 7/8 inch connector (5-pin, Socket): 1 pc.

EX245-SPN1A EX245-SPN2A EX245-SPN3A



# JSY3000/5000 Series

## Manifold Parts Nos.

③ EX245 digital input module

EX245-DX1

Digital input module specification
 DX1 Digital input (16 inputs)

③ EX245 digital output module

EX245-<u>DY1</u>

Digital output module specification
 DY1 Digital output (8 outputs)





③EX245 IO-Link module

# EX245-L<u>A</u>1


<ul> <li>Port specification</li> </ul>		
Symbol	Description	
Α	Port class A	
В	Port class B	



## 

The only available SI unit part number is "EX245-SPNmA" (PROFINET compatible). Refer to page 131.

④ EX245 end plate







\* Refer to page 94 for manifold valve part numbers.

Bracket 3 to 5 correspond to the mounting hole pitch of each manifold valve.

## туре 10 Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series



## Manifold Parts Nos.



The 3/5(E) port is plugged for the built-in

.

ΦP, E	P, E port size (One-touch fittings)			
Symbol	P, E port	JSY1000	JSY3000	JSY5000
C8	ø8 One-touch fitting	•	—	—
C10	ø10 One-touch fitting	_	•	_
C12	ø12 One-touch fitting	—	—	•
<b>00</b> *1	Plug	•	•	

\*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type

#### SUP/EXH block assembly (D side) accessories and the number of accessories

.

.

	Accessories	JSY1000 JSY3000	JSY5000
Г	a Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block

## ④ Input block



#### Block type

1	M12 connector, 2 inputs	
2	M12 connector, 4 inputs	
3	M8 connector, 4 inputs	

## (5) EX250 end plate assembly

## EX250-EA1

\* With mounting screws (2 pcs. of M3 x 10)

6 Clamp bracket assembly for EX250

## SY30M-15-3A


\* The part number is for 1 assembly.

## 2 EX250 SI unit

silencer type.

s

R



•

.

## Communication protocol


DN1	DeviceNet® (Negative common)
AS3	AS-Interface (8 in/8 out, 2 isolated common type) (Negative common)
AS5	AS-Interface (4 in/4 out, 2 isolated common type) (Negative common)
AS7	AS-Interface (8 in/8 out, 1 common type) (Negative common)
AS9	AS-Interface (4 in/4 out, 1 common type) (Negative common)
EN1	EtherNet/IP <sup>™</sup> (Negative common)

#### ③Clamp bracket


*	
Series	Part no.
JSY1000	JSY11M-15P-2A
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A

\* The part number is for 1 piece.





## **Manifold Parts Nos**



## 2 EX260 SI unit (Fieldbus and Industrial Ethernet)

#### SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000/3000	JSY5000
a Tension bolt	None*1	3 pcs.

\*1 Since the nuts are embedded in the SUP/EXH block

## EX260-SPR1 Communication protocol

Symbol	Protocol	Number of outputs	SI unit output polarity	Communication connector	Manifold symbol	Symbol	Protocol	Number of outputs	SI unit output polarity	Communication connector	Manifold symbol
DN1		32	Source/PNP (Negative common)		QAN	EC1		32	Source/PNP (Negative common)		DAN
DN2	DeviceNet®	32	Sink/NPN (Positive common)	M12	QA	EC2	EtherCAT		Sink/NPN (Positive common)	M12	DA
DN3	Deviceivel	16	Source/PNP (Negative common)	IVI 12	QBN	EC3		16	Source/PNP (Negative common)	IVITZ	DBN
DN4		10	Sink/NPN (Positive common)		QB	EC4		10	Sink/NPN (Positive common)		DB
PR1		32	Source/PNP (Negative common)		NAN	PN1		32	Source/PNP (Negative common)		FAN
PR2		52	Sink/NPN (Positive common)	M12	NA	PN2	PROFINET		Sink/NPN (Positive common)	M12	FA
PR3		16	Source/PNP (Negative common)	IVITZ	NBN	PN3		16	Source/PNP (Negative common)	IVITZ	FBN
PR4	PROFIBUS DP	10	Sink/NPN (Positive common)		NB	PN4			Sink/NPN (Positive common)		FB
PR5	111011003 01	32	Source/PNP (Negative common)		NCN	EN1		32	Source/PNP (Negative common)		EAN
PR6		32	Sink/NPN (Positive common)	D-sub*1	NC	EN2	EtherNet/IP™		Sink/NPN (Positive common)	M12	EA
PR7		16	Source/PNP (Negative common)	D-305	NDN	EN3		16	Source/PNP (Negative common)	IVITZ	EBN
PR8		10	Sink/NPN (Positive common)		ND	EN4		10	Sink/NPN (Positive common)		EB
MJ1		32	Source/PNP (Negative common)		VAN	PL1	Ethernet	32	Source/PNP (Negative common)	M12	GAN
MJ2	CC-Link	JZ	Sink/NPN (Positive common)	M12	VA	PL3	POWERLINK	16		IVITZ	GBN
MJ3		16	Source/PNP (Negative common)	IVI 12	VBN	IL1	IO-Link	32	Source/PNP (Negative common)	M12	KAN
MJ4		10	Sink/NPN (Positive common)		VB						

\*1 Enclosure is IP40 when the communication connector is D-sub.

## EX260 SI Unit (Safety Communication)

# EX260-F PS1

## Communication protocol

Symbol Protocol Number of outputs SI unit output polarity Communication connector Manifold symbol PS1 PROFIsafe 32 Source/PNP (Negative common) M12 FPN

## 134




#### 3 Clamp bracket

Series	Part no.
JSY1000	JSY11M-15P-1A
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A


\* The part number is for 1 piece.

## туре 10 Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series



depending on wiring. Refer to page 161.

## Manifold Parts Nos.



\*1 Since the nuts are embedded in the SUP/EXH block

EX120-S DN1

#### Communication protocol

DN1	DeviceNet® (Positive common)
CS1	OMRON Corp.: CompoBus/S (16 outputs) (Positive common)
CS2	OMRON Corp.: CompoBus/S (8 outputs) (Positive common)
MJ1	CC-Link (Positive common)
CM1	CompoNet <sup>®</sup> NPN (Positive common)
CM3	CompoNet <sup>®</sup> PNP (Negative common)

#### ③Clamp bracket


Series	Part no.
JSY1000	JSY11M-15P-1A
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A

\* The part number is for 1 piece.


**JSY5000** 

3 pcs.

# Manifold Exploded View [Common Parts]



## Type 10: How to Increase Connector Type Manifolds



@SMC

## For the JJ5SY1-10, JJ5SY3-10, JJ5SY5-10

No.		Description	JSY1000		JSY3000	JSY5000	Note	
140.		Description	6.5 mm pitch	9 mm pitch	3313000	3313000	Note	
<b>A-</b> ①	v ock	Base gasket (for connector connecting base)	JSY11M	/I-9P-1A	JSY31M-9P-1A	JSY51M-9P-1A	Part numbers shown on the left are for 10 valves. (10 pcs.)	
<b>A-</b> 2	] ă 🚡	Connector gasket	-	_	SX3000	)-146-2	Supplied individually	
<b>A-</b> 3	nifold	Manifold block gasket	JSY11M-9P-2		JSY31M-9P-2	JSY51M-9P-2	Supplied individually	
<b>A-</b> ④	Mai	Tie-rod for	JSY11M-49P-1-1-A	JSY11M-49P-2-1-A	JSY31M-49P-1-1-A	SV2000-55-2A-A	3 pcs. supplied	
<b>H-</b>	-	additional stations*1	(6.5 mm pitch)	(9 mm pitch)	(11.5 mm pitch)	(16 mm pitch)	5 pcs. supplied	
(5)	Tie-I	and a second	JSY11M-49P-1-D-A	JSY11M-49P-2-D-A	JSY31M-49P-1-□-A	SV2000-55-1-□-A	: Manifold stations (2 to 24	
9	l lie-i	rou	(6.5 mm pitch)	(9 mm pitch)	(11.5 mm pitch)	(16 mm pitch)	stations) 3 pcs. supplied	
6)	<b>J</b>		JSY11		JSY31V-23-1A	JSY51V-23-1A	Part numbers shown on the	
-			(M1.4	x 21.5)	(M2 x 25) (M3 x 29)		left are for 10 valves. (20 pcs.)	
7	DIN rail			VZ1000-11-1-		VZ1000-11-4-□	Refer to page 152.	
8	8 Clamp bracket*2 (for connector connecting base)		JSY11M-15P-1A (Ref JSY11M-15P-2A (Ref	fer to the table below.)*2 fer to the table below.)	SY30M-15-1A	SY50M-15-1A	Supplied individually	


\*1 The manifold of the JSY1000/3000 (JJ5SY1-10/JJ5SY3-10) can be assembled by connecting the tie-rods for number of manifold stations. The manifold of the JSY5000 (JJ5SY5-10) cannot be assembled by connecting the tie-rods for additional stations for the number of manifold. Tie-rod (SV2000-55-1-□-A) is necessary.

\*2 Part number of the clamp bracket for the JSY1000 is different depending on the manifold wiring. Refer to the table below. Refer to page 161 for assembly.


#### Table. JSY1000 series clamp bracket

	Wiring (JSY1000 series)	JSY11M-15P-1A	JSY11M-15P-2A
F	D-sub connector	•	—
P	Flat ribbon cable	•	—
TC	Spring type terminal block box	•	—
Т	Terminal block box	-	•
L	Lead wire	•	—
S6	EX600	_	•
S	EX250	_	•
S	EX260	•	—
S3	EX120	•	—

## Manifold Parts Nos



Symbol	A D mont	JSY1000		1673000	JSY5000	
Symbol	A, B port	6.5 mm pitch	9 mm pitch	3313000	3315000	
C2	ø2 One-touch fitting	•	—	—	—	
C4	ø4 One-touch fitting	•	—	—	—	
C6	ø6 One-touch fitting	-	•	•	_	
C8	ø8 One-touch fitting	-	_	•	—	
C10	ø10 One-touch fitting	-	_	—	•	
C12	ø12 One-touch fitting	_		_	•	




#### Manifold block assembly accessories and the number of accessories

Accessories	Quantity
1 Base gasket	1 pc.
② Connector gasket*1	1 pc.
3 Manifold block gasket	1 pc.
④ Tie-rod for additional stations	3 pcs.

\*1 Not applicable to the JSY1000 series

## Manifold Parts Nos.



 Cover, silencer cover, and port block are included in the SUP/EXH (end) block assembly, but they need to be ordered for piping specification change.
 Mounting screws (2 pcs.) for SUP/EXH end block assembly are included.

Tightening torque for mounting screw JSY1000 (M2.5): 0.32 N·m JSY3000 (M3): 0.8 N·m JSY5000 (M4): 1.4 N·m

**SMC** 

3 JSY3000

1 JSY1000

5 JSY5000

## A Caution

- Be sure to shut off the power and air supplies before disassembly. Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before performing any work.
- When disassembly and assembly are performed, air leakage may result if the tightening of the cover and port block assemblies are inadequate.



## Plug-in Connector Connecting Base Vacuum Unit ZK2 Combination Manifold RoHS Type 10 Side Ported

# Y3000 Series

Specify the valve manifold and mounted valve part numbers as well as the elector manifold and mounted ejector part numbers for ordering. Refer to page 141 for an order example.

JJ5SY

#### Internal Pilot

## How to Order Manifolds

# Valve Manifold

JSY3000

Series

#### Connector type, Wiring, Number of cores. SI unit

Symbol Type Page					
Symbol	Туре	15.40	Page		
F	D-sub connector	IP40			
FW	(25 pins)	IP67			
FC	(20 pino)	IP20			
Р		26 pins			
PG	Flat ribbon cable	20 pins	42		
PH		10 pins			
PC	Flat ribbon cable	26 pins			
PGC	Compact type	20 pins			
PHC	compact type	10 pins			
TC	Spring type terminal	block box	64		
Т	Terminal block	box	04		
L1		34 cores			
L2	Lead wire	17 cores	76		
L3		9 cores			
S6🗆		EX600	84		
S	Carial	EX245	94		
S	Serial transmission	EX250	98		
S		EX260	104		
S3🗆		EX120	112		
. Defen	An Alex we want alex				

\* Refer to the pages shown in the table above for details.

## P, E port entry, SUP/EXH block assembly

Symbol	P, E port entry	SUP/EXH block assembly	Application		
U	U side (2 to 10 stations)				
D	D side (2 to 10 stations)	Internal pilot	All		
В	Both sides (2 to 24 stations)				
US	U side (2 to 10 stations)	Internal pilot,	D-sub connector (FD), Terminal block box (TC, T),		
DS			Flat ribbon cable (P ), Lead wire (L )		
BS	Both sides (2 to 24 stations)	silencer	EX260(S□)/EX245(S□)/EX120(S3□)		
С	U side (2 to 10 stations)	Internal pilot,			
E	D side (2 to 10 stations)	Built-in	EX600(S6□) EX250(S□)		
F	Both sides (2 to 24 stations)	silencer	EA230(SL)		

\* The 3/5(E) port is plugged for the built-in silencer type.

- \* When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156

#### 8 A, B port size (Metric/One-touch fitting)

Symbol	A, B port	P, E port
C6	Straight ø6	
C8	Straight ø8	ø10
<b>CM</b> *1	Straight port, mixed sizes	


\*1 Indicate the sizes on the manifold specification sheet in the case of "CM"



4 • Connec	tor entry direction (F□/P□)			
Symbol	Туре			
1	Upward			
2	Downward			
Lead wire length (1 1/1 2/1 3)				

- Louu	Lead whe length (L1/L2/L0)			
Symbol	Туре			
1	0.6 m			
2	1.5 m			
3	3 m			

- · SI unit output polarity, End plate type (S6 ) Refer to page 84.
- With or without I/O modules (S
  ) Refer to page 94
- Input block stations (S
  ) Refer to page 98.



Number of I/O modules (S Refer to page 94.

Input block type (S Refer to page 98.

## 6 Valve stations

05 DS


· For 32 output points (TC/L1/S6□/S□)				For 24 output points     (F/FW/FC/P/PC)				
Symbol	Stations	Note	Syr	mbol	Stations	Note		
02	2 stations		0	)2	2 stations			
	:	Double wiring*1	ouble wiring*1		:	Double wiring*		
15	15 stations	-		1	11 stations			
02	2 stations	Specified layout*2	0	)2	2 stations	Specified layout*2		
		(Up to 30 solenoids		:	:	(Up to 22 solenoids		
24	24 stations	available)	22		22 stations	available)		
For 2	20 outp	ut points(T)	۰F	or 1	8 output	t points (PG/PGC		
Symbol	Stations	Note	Syr	mbol	Stations	Note		
	Stations 2 stations	Note	<u> </u>		Stations 2 stations			
		Note Double wiring*1	<u> </u>					
			C			Double wiring*1		
02 :	2 stations :	Double wiring*1	C	)2 :	2 stations :	Double wiring*1		
02 : 09	2 stations : 9 stations	Double wiring*1	C	)2 : )8	2 stations : 8 stations 2 stations	Double wiring*1		
02 : 09	2 stations : 9 stations	Double wiring*1 Specified layout*2 (Up to18 solenoids		)2 : )8	2 stations : 8 stations 2 stations	Double wiring <sup>*1</sup> Specified layout <sup>*2</sup> (Up to 16 solenoids		

#### PH/PHC/L3) Symbol Stations Note Symbol Stations Note 02 2 stations 02 2 stations Double wiring\*1 Double wiring\*1 07 7 stations 03 3 stations 02 2 stations Specified layout\*2 02 2 stations Specified layout\*2 (Up to 14 solenoids (Up to 6 solenoids 14 14 stations available) 06 6 stations available)

\*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal.

\*2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)

- The total number of solenoids for the valve and elector should not exceed the number of output points. (Number of ejector solenoids: 2 per station)
- This also includes the number of blanking plates.
- For models without an SI unit (S0), note the number of output points of the SI unit that will be mounted.



Refer to page 160 for details on securing the DIN rail mounting type manifold.



How to Order

JSY3000 pp. 140, 141

How to Order

ZK2 pp. 142, 143


Combination manifold

# Plug-in Connector Connecting Base Vacuum Unit ZK2 Combination Manifold

JSY3000 Series

Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to the bottom of this page for an order example.

Internal Pilot




# Base mounted

U Ser	les
3	JSY3000

<b>3</b> Pilot valve exhaust method				
	0	Pilot valve individual exhaust		

4 Rated	d voltage	



2 Type of actuation					
1	2-position	Single			
2	2-position	Double			
3		Closed cer			
4	3-position	Exhaust ce			

3		Ciosed certier			
4	3-position	Exhaust center			
5		Pressure center			
Α	4	N.C./N.C.			
В	4-position dual 3-port	N.O./N.O.			
С	uuai 3-port	N C /N O			

#### Uight/surge voltage suppressor and common specification


Symbol	With light	Surge voltage suppressor	Common specification					
U			Non-polar					
Z	•	•	Positive common					
NZ			Negative common					

\* When the non-polar common specification type is selected, take measures to prevent surge voltage. For details, refer to page 159.

\* For fieldbus compatible manifolds, ensure that the output polarity of the SI unit matches the common specification of the valve. Note that the common specification of the ejector is non-polar.




#### 6 Manual override



#### When ordering a valve individually, the base gasket is not included. Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.

## How to Order Manifold Assembly



Refer to pages 121 and 122 for how to order ZK2 vacuum units.

- JJ5SY3-10SFA-05D-C8-M ... 1 set (Type 10 5-station manifold base part no.)
- JSY3100-5U ...2 sets (2-position single valve part no.) \* JSY3200-5U ···3 sets (2-position double valve part no.)
- \* ZZK204A-A1S0 .....1 set (Ejector manifold part no.)
- \* ZK2C12K5NC1A-08------4 sets (Ejector unit part no.)

The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the ejector manifold, valve, etc.

- For the valve and ejector arrangement, the valves closest to the D side are considered the 1st stations respectively.
- Under the manifold part number, state the valves, ejector manifold, and ejector units to be mounted in order starting with the 1st station as shown in the figure
- · Complex exhaust and individual port exhaust cannot be mixed in the ejector manifold
- · If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

## ▲ Caution


If the product is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification. Refer to "Made to Order" on page 156.



# JSY3000 Series

Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to page 141 for an order example.

## How to Order Manifolds




•••	autonio	
Symbol	Stations	:
01	1 station	
02	2 stations	
:	:	
08	8 stations	

Stations\*1

1 For adequate performance, the number of stations that can be operated simultaneously depends on the nozzle diameter. For details, refer to the ZK2 A series catalog.

2 System/Port				
Symbol	System	Port		
Α	Ejector system	ø8 (Common PV)		

Exhaust



\*2 Combination of direct exhaust and end plate exhaust from each station

## Supply valve and release valve wiring<sup>\*3</sup>

s	Symbol	Wiring	ing Selectable wiring for r (Refer to "How to C Ejectors" on page	
			С	C1
	S0	Centralized wiring	•	•

\*3 Individual wiring is specified for pressure switches for vacuum and sensors.

## • Option\*4

Symbol	Туре		Selectable options for manifold (Refer to "How to Order Ejectors" on page 143.)					
		E	J	K	L	Р	W	
Nil	Without option		•	•	_	_	•	
В	With DIN rail mounting bracket*5		•	•	_	_	•	
D	With common release pressure supply (PD) port		•	٠	-	0*6	•	
L	Manifold individual supply specification	•	•	•	©*6	_	•	

\*4 When more than one option is selected, list the option symbols in alphabetical order. (Example -BD)

\*5 Be sure to select the DIN rail mounting for the mounting method of the valve manifold.

\*6 When option "D" is selected, select option "P" for the single unit for manifold. When option "L" is selected, select option "L" for the single unit for manifold. (
 must be selected.)

\* For details, refer to "Optional Specifications/Functions/Applications" below.

## **Optional Specifications/Functions/Applications**

Symbol			Туре	Function/Application		
E	Screwdriver operation type long lock nut			<ul> <li>Used when the port position is close to the manifold's individual supply and needle adjustment is difficult</li> </ul>		
J	Vacuum break flow adjusting needle	Round lock nut		Thicker than the standard hexagon type     More suitable for hand tightening     The round lock nut improves operability when the manifold or exhaust port type is used.		
к		Screwdriver operation type		The slotted type allows for fine adjustment when the manifole     or exhaust port type is used.		
L	Manifold individ supply specific		Individual supply port	· For adjusting the manifold's supply pressure and the vacuum pressure reached by each ejector individually		
Р	With manifold common release pressure supply (PD) port		supply (PD) port) a pressure which is different from			
w	With exhaust interference prevention valve Exhaust interference			<ul> <li>When ejectors are operated individually, exhausted air may flow backward from the V ports of ejectors that are turned off. The exhaust interference prevention valve prevents this backflow.</li> </ul>		

## Plug-in Connector Connecting Base

Vacuum Unit ZK2 Combination Manifold




Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to page 141 for an order example.

For ejector specifications, refer to the Web Catalog.

How to Order Ejectors

15

diameter.



Body/Exhaust type					
Symbol	Body	Exh	aust type		
с	For Manifold	Complex exhaust*1	Direct exhaust End plate exhaust		
F		Individual port exhaust	Individual port exhaust		
н		High-noise reduction silencer exhaust	High-noise reduction silencer exhaust		

\*1 Combination of direct exhaust and end plate exhaust from each station

## 5 Pressure switch for vacuum/Pressure sensor

		Pressure range [kPa]	Specifications			
Symbol	Туре		NPN	PNP	With unit selection	
		range (ki aj	2 ou	tputs	function*3	
Α			•	—	•	
В	for	0 to -101	•	—	None (SI unit only)	
С	L C	010-101	—	•	•	
D	swi		—	•	None (SI unit only)	
E	act		•	—	•	
F	Pressure switch for vacuum	-100 to 100	•	—	None (SI unit only)	
Н	P.	-100 10 100	—	•	•	
J			-	•	None (SI unit only)	
Ρ	Pressure	ssure 0 to -101				
Т	sensor	-100 to 100	Analog output 1 to 5 V			
N	Without p	ressure switch for	or vacuum/pressure sensor			

IN \*3 The unit selection function is not available in Japan due to the

New Measurement Law. The unit for the type without the unit selection function is fixed as kPa.

## Vacuum (V) port

Symbol	Vacuum (V) port	
06	ø6	
08	ø8	

<b>2</b> N	ominal nozzle size	
Symbol	Nominal nozzle size	_
07	ø0.7	
10	ø1.0	Ì
12	ø1.2	

ø1.5 Refer to the ZK2 A series catalog for the standard

supply pressure per nozzle

#### 3 Combination of supply valve and release valve

Symbol	Supply valve		Release valve	
Symbol	N.C.	Self-holding	N.C.	
к	•	-	•	
J	•	_	_	
R	-	●* <sup>2</sup>	•	

\*2 Supply valve maintains vacuum by energization (20 ms or more). Stopping the vacuum turns on the release valve.

4 Rated voltage						
(Supply valve/Release valve)						
Symbol	Voltage					

oymbor	Voltage
5	24 VDC



#### (Supply valve/Release valve/Pressure switch for vacuum)

	(					
Symbol	For supply valve/ release valve	switch for vacuum: accombly: 3 r		ewitch for voouum: Pressure sensor		Note
	Centralized wiring specification (Plug-in)	2 m (Lead wire with connector)	(With lead wire)	inote		
с	•	•		Cannot be selected when (5) is N		
C1	Non		ne	Cannot be selected when (3) is P or T		


8 Option\*4 (For details on the Function/Application, refer to page 142.)

Symbol		T	уре	Note
Nil	Without o	ption	-	
Е	k flow edle	Screwdriver operation type long lock nut	on Screwdriver operation type long lock nut	Cannot be selected when 3
J	/acuum break flow adjusting needle	Round lock nut		is J Can be selected only for the
к	Vacu adju	Screwdriver operation type	Vacuum break flow adjusting needle	combination of J and K
L	Manifold individual supply specification*5 supply port			-
Р	With manifold common release pressure supply (PD) port			Cannot be selected when (3) is J
w	With exhapreventio	aust interference n valve	Exhaust interference prevention valve	When J is selected for <b>③</b> , install the release valve or vacuum breaker in the middle of the vacuum piping.

\*4 When more than one option is selected, list the option symbols in alphabetical order. (Example -EL)

\*5 When F or H is selected for 1 and L is selected for the option, the space for adjusting the needle is reduced. Products which can be operated more easily can be specified by option E or K.

# JSY3000 Series



**SMC** 


- Refer to pages 90, 91, and 102 for dimensions when L6 and b are used for the calculation
- formula. \* Refer to the reference pages shown in the table to the right for dimensions that are not specified in each wiring specification.

Calculation formula for dimensions
L1 = 11.5 x n1 + 15 x n2 + a + b x n3 + e
L2 = 11.5 x n1 + 15 x n2 + e + 93.7
M = (L1 + c)/12.5 + 1 Decimal fractions are truncated.
L3 = 12.5 x M + 23
L4 = L3 - 10.5
L5 = (L3 - L1 + c)/2
L6 = b x n3 + 82
L7 = 15 x n2 + 41.5

n1: Number of valve stations of the JSY3000 n2: Number of ejector stations of the ZK2A n3: Number of I/O units or input block stations

	а	b	с	page
D-sub connector (IP40/Connector entry direction adjustable)	120.4	-	6.1	46
D-sub connector (IP67)	135.2	_	4.5	48
D-sub connector (IP20/Compact type)	133.4	_	6.1	52
Flat ribbon cable (IP40/Connector entry direction adjustable)	120.4	-	6.1	55
Flat ribbon cable (IP20/Compact type)	114.9	_	11.2	59
Spring type terminal block box	172.7	_	—	68
Terminal block box	194	-	—	72
Lead wire	141.7	_	_	80
Serial transmission: EX600 (M12 connector)	186.2	47	—	90
Serial transmission: EX600 (7/8 inch connector)	202.7	47	—	91
Serial transmission: EX245	217.8	54	—	96
Serial transmission: EX250	186.2	21	—	102
Serial transmission: EX260	133.4	_	—	110
Serial transmission: EX120	138.5	_	—	116
Coefficient	е			
D side entry	_			
U side/Both sides entry	23			

## Dimensions



\*1 The common pilot pressure supply (PS) port is only available when manifold option "L" (manifold individual supply specification) is selected.

\*2 The common supply (PD) port is only available when manifold option "D" is selected.


Long lock nut


# JSY3000 Series




Dimensions: JSY3000 Series


JJ5SY3-10 - Stations B(S, R)-M







# JSY3000 Series ZK2 Combination Manifold Exploded View



\* For details on the ZK2 ejector unit and replacement parts for the manifold, refer to the ZK2 are series catalog.

## For the JJ5SY3-10-M (ZZK2 A)

#### 9 Manifold end plate assembly

The assembly number includes end plate D, end plate U, and a tension bolt assembly.

# ZZK2 \_\_\_\_\_ S0-\_\_\_-


[	No.	Description	ZK2	Note			
[	10	Clamp bracket	ZK2-DA5-A	2 pcs. per set			
ĺ	1	DIN rail mounting spacer	ZK2-EU3-A				

Refer to page 142 for the manifold part number.

Manifold end plate assembly

# JSY3000 Series


## Manifold Parts Nos.



before performing any work. 2. When disassembly and assembly are performed, air leakage may result if the tightening of the cover and port block assemblies are inadequate.

# *JSY3000 Series* ZK2<sup>\_\_</sup>A Vacuum Ejector Manifold Exploded View

# How to Increase Manifold Stations



# [To increase the number of stations from an odd number (1, 3, 5, 7) to an even number (2, 4, 6, 8)]

(Odd numbered stations have a vacant lead wire for one station, so additional orders are not required.)

- 1) Remove the tension bolt.
- 2) Remove end plate U.
- 3) Remove the valve assembly from the single unit for manifold to be added.
- Remove the switch assembly if there is one. (Be careful not to drop the O-ring. Refer to Fig. 1.)
- 5) Remove junction box B (top) using a precision screwdriver. (Refer to Fig. 2.)
- 6) Mount the extra connector to junction box B. (Refer to Fig. 3.) (Engage the recess of the connector and the protruding part of junction box B. Refer to Fig. 3-A.)
- 7) Mount the single unit for manifold to be added to the end surface on the U side.
- Mount end plate U with tension bolts of the appropriate length for the number of stations required. (Tightening torque: 0.75 N·m)
- 9) Mount junction box B to junction box A.
- 10) Mount the valve assembly. (Tightening torque: 0.15 N·m)
- For products with a switch, mount the switch assembly. (Be careful not to drop the O-ring. Tightening torque: 0.08 to 0.10 N-m)

#### [To increase the number of stations from an even number to an odd number or to increase by 2 stations or more]

- Remove the valve assemblies from all stations. (Remove from the single units to be added also.)
- 2) Remove the switch assemblies if there are any. (Be careful not to drop the O-rings. Refer to Fig. 1.)
- Remove junction box B (top) from all stations using a precision screwdriver. (Refer to <u>Fig.2</u>.) (Remove each junction box B from the D side.)
- Remove all connectors mounted to each junction box B. (Be careful not to break the connector clips.)
- 5) Remove the tension bolts.
- 6) Remove the end plate D assembly.
- Remove the linkage-printed circuit board, and then remove the connector assembly. (Refer to Fig. 4.)
- 8) Connect the lead wire assembly. (Refer to Fig. 5.)
- Remount the connector assembly and linkage-printed circuit board. (Refer to Fig. 4.)
- 10) Remove end plate U. (Be careful not to drop the gasket.)11) Mount the single units for manifold to be added to the end
- surface on the U side. (Do not let the gasket get caught.)
  12) Mount end plates U and D with tension bolts of the appropriate length for the number of stations required.
- (Tightening trque: 0.75 N·m) 13) Mount the connectors for all stations to each junction box B. (Befor to  $\frac{1}{2}$ ) (Forease the reason of the connector and
- (Refer to Fig. 3.) (Engage the recess of the connector and the protruding part of junction box B. Refer to Fig. 3-A.)
   14) Mount each junction box B to each junction box A.
- Push the wires down and mount each junction box B to each junction box A starting with the connector station numbers on the U side. (Refer to Fig. 6.) (Do not let the lead wire get caught.)
- 15) Mount the valve assemblies. (Tightening torque: 0.15 N·m)
- 16) For products with a switch, mount the switch assemblies. (Be careful not to drop the O-rings. Tightening torque: 0.08 to  $0.10 \text{ N} \cdot \text{m}$ )

<sup>(2)</sup>Lead wire assembly ZK2 – CHS 04 – A

● Ap	Applicable stations									
03	For 3-station manifold									
:										
08	For 8-station manifold									

# JSY3000 Series


## How to Increase Manifold Stations: Vacuum Ejector Manifold for JSY3000

## Connect the lead wire assembly to the positions shown in the diagram below.

**Caution** 1) After inserting each pin, confirm that the pin is locked by lightly pulling the lead wire.


2) Do not pull the lead wire forcefully when connecting. Also, take care that lead wires do not get caught between manifolds when mounting end plates U and D.

#### Wiring



# *JSY1000/3000/5000 series* One-touch Fittings, Plug, Clip, Port Plate, Tube Releasing Tool

Refer to "How to Replace One-touch Fittings" on page 160 for the replacement method.



### ①One-touch Fittings

		0					
/	Series	JSY	1000	JSY3000	JSY5000	Note	
Port size	$\sim$	6.5 mm pitch	9 mm pitch	3313000	3313000	Note	
	ø2	KQSY10-C2	—	—	—		
	ø4	KQSY10-C4-X1336	—	—	—		
A D nort	ø6	_	KQSY11-C6-X1336	KQSY30-C6	_		
A, B port	ø8	-	-	KQSY30-C8-X1336	_		
	ø10	-	-	_	KQSY50-C10	The part number is for 1 piece. (Sales unit: 10 pcs.)	
	ø12	-	-	-	KQSY50-C12-X1336	(Sales unit. To post)	
	ø8	KQSY30-	C8-X1336	_	_		
P, E port	ø10	-	-	KQSY31-C10-X1336	—		
	ø12	-	-	—	KQSY50-C12-X1336		

\* Refer to page 160 for assembling when a fitting is replaced.

#### 2 Plug

Series Piping port	JSY1000	JSY3000	JSY5000	Note
P, E port	JSY11M-62P-1A	JSY31M-62P-1A	JSY51M-62P-1A	The part number is for 1 piece.

\* A, B port plug does not exist. Use the KQ2P series.

#### **3 Clip, Port Plate**


Series	JSY	1000				
Piping port	For A, B port C2/C4 fittings		JSY3000	JSY5000	Note	
A, B port (Clip)			JSY31M-19P-1A	JSY51M-19P-1A	The part number is for 10 pieces.	
P, E port (Port plate)	JSY11M	/I-10P-1	JSY31M-10P-1	JSY51M-10P-1	The part number is for 1 piece.	

\* Refer to page 160 for assembling when a fitting is replaced.

#### Tube Releasing Tool (This tool can be used to remove tubes from ports A and B.)

Series	For JS	Y1000	For JSY3000	For JSY5000	
Series	6.5 mm pitch	9 mm pitch	F01 33 13000		
Part no.	TG-0204	TG-0608	TG-0608	TG-1012	
Applicable tubing O.D.	ø2/ø4	ø6	ø6/ø8	ø10/ø12	








# *JSY1000/3000/5000 Series* Manifold Options

# ■ DIN rail dimensions/weight for the JSY1000/3000 Pugen connector connecting base VZ1000-11-1-□


\* After confirming the L3 dimension in the dimensions table of each series, refer to the DIN rail dimensions table below and specify the number in the box D.



No.	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
L dimension	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5	323
Weight [g]	17.6	19.9	22.1	24.4	26.6	28.9	31.1	33.4	35.6	37.9	40.1	42.4	44.6	46.9	49.1	51.4	53.6	55.9	58.1
No.	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37
L dimension	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5
Weight [g]	60.4	62.5	64.9	67.1	69.4	71.6	73.9	76.1	78.4	80.6	82.9	85.1	87.4	89.6	91.9	94.1	96.4	98.6	100.9
No.	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56
L dimension	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798
Weight [g]	103.1	105.4	107.6	109.9	112.1	114.4	116.6	118.9	121.1	123.4	125.6	127.9	130.1	132.4	134.6	136.9	139.1	141.4	143.6
No.	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71				
L dimension	810.5	823	835.5	848	860.5	873	885.5	898	910.5	923	935.5	948	960.5	973	985.5				
Weight [g]	145.9	148.1	150.4	152.6	154.9	157.1	159.4	161.6	163.9	166.1	168.4	170.6	172.9	175.1	177.4				

# ■ DIN rail dimensions/weight for the JSY5000 Pugen connector connecting base VZ1000-11-4-□

\* After confirming the L3 dimension in the dimensions table of each series, refer to the DIN rail dimensions table below and specify the number in the box 🗆.



No.	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
L dimension	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5	323
Weight [g]	24.8	28	31.1	34.3	37.4	40.6	43.8	46.9	50.1	53.3	56.4	59.6	62.7	65.9	69.1	72.2	75.4	78.6	81.7
No.	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37
L dimension	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5
Weight [g]	84.9	88	91.2	94.4	97.5	100.7	103.9	107	110.2	113.3	116.5	119.7	122.8	126	129.2	132.3	135.5	138.6	141.8
No.	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56
No. L dimension	38 573	39 585.5	40 598	41 610.5	42 623	43 635.5	44 648	45 660.5	46 673	47 685.5	48 698	49 710.5	50 723	51 735.5	52 748	53 760.5	54 773	55 785.5	56 798
-	573					-		660.5			-		723		-		÷.	785.5	
L dimension	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798
L dimension Weight [g] No.	573 145	585.5 148.1	598 151.3	610.5 154.5	623 157.6	635.5 160.8	648 163.9	660.5 167.1	673 170.3	685.5 173.4	698 176.6	710.5 179.8	723 182.9	735.5 186.1	748 189.2	760.5	773	785.5	798

# Manifold Options JSY1000/3000/5000 Series

## Caution Tightening torque for mounting screw

#### M1.4: 0.06 N·m (JSY1000) M2: 0.16 N·m (JSY3000) M3: 0.8 N·m (JSY5000)

## **Manifold Options**


#### Blanking plate

[With two mounting screws] Used when valve additions are expected or for maintenance



JSY11M-26P-1A






#### 

Refer to page 155 for dimensions.

Circuit diagram


#### Individual SUP spacer


[With a connector gasket, a base gasket, and two mounting screws] When the same manifold is to be used for different pressures, an individual SUP spacer assembly can be used to act as a supply port for different pressures.



#### Individual EXH spacer

[With a connector gasket, a base gasket, and two mounting screws] When valve exhaust affects other stations due to the circuit configuration, this spacer can be used for individual valve exhaust.





#### Port size (One-touch fittings)

Symbol	P, E port	JSY1000	JSY3000	JSY5000
C4	ø4 One-touch fitting	•	-	-
C6	ø6 One-touch fitting	-	•	-
C8	ø8 One-touch fitting	-	_	•
C10	ø10 One-touch fitting	-	-	•
C12	ø12 One-touch fitting	—	—	•



**∧**Caution

Tightening torque for mounting screw M1.4: 0.06 N·m (JSY1000)

## Manifold Options

\* Refer to page 155-1 for dimensions.

SUP stop valve spacer with residual pressure release valve [With a base gasket and two mounting screws]

It is used to shut off the supply air to valves individually.

# Base gasket Pug-in space Base gasket Mounting screw (2 pcs.) Manual override Manual override

[How to mount SUP stop valve spacer with residual pressure release valve] Mount the plug-in spacer to the manifold block.

Insert the SUP stop valve mounting screw into the spacer screw hole, and mount it to the manifold block.

Tighten the SUP stop valve mounting screw to the specified tightening torque. Mount the valve and tighten the valve mounting screws to the specified tightening torque after mounting the SUP stop valve spacer with residual pressure release valve.

- \* Be aware that the square nut may come off. If the square nut comes off, attach it to the spacer as shown in the drawing.
- \* Tightening with a hexagon wrench is possible with the square nut attached.
- This product is only for internal pilot specifications, as the external pilot air cannot be shut off.
- If the product is equipped with a 3-position closed center, residual pressure cannot be released, so use in combination with a 3-port valve, which can be connected to the 4(A), 2(B) piping port.
- \* Note that other spacer combinations are not possible.

	Port	size	Flow rate characteristics					
Model	1, 3/5	4, 2	1 → 4/2(P -	→ A/B)	$4/2 \rightarrow 3/5(A/B \rightarrow E)$			
	(P, E)	(A, B)	C [dm3/(s·bar)]	b	C [dm³/(s·bar)]	b		
JSY11M-50P-1A	C8	C6	0.65	0.21	0.86	0.36		

JSY1000: Z2-SR1-A (10 pcs.)

\* Calculation of effective area S and sonic conductance C: S = 5.0 x C

The value is for manifold base with 5 stations and individually operated 2-position type.

\* For connector connecting base (type 10) manifolds


\* Only compatible when the JSY1000 series 4(A), 2(B) ports are port size C6

## JSY11M-50P-1A

Manual	Push-turn locking
override	slotted type

If you want to lock the manual override, push it down until it stops, and then turn it 90° clockwise. Be careful to avoid turning it without pushing it all the way down as this may result in spacer damage, air leakage, or another form of malfunction.

To release the manual override, turn it counterclockwise. When turning the manual override, do not apply more torque than necessary. (0.1  $N{\cdot}m)$ 



**⊘**SMC

## **Manifold Options**

#### SUP/EXH blocking disk

#### [SUP blocking disk]

Inserting an SUP blocking disk in the pressure supply passage of a manifold valve can allow for the use of 2 different pressures (high and low) in 1 manifold.

#### [EXH blocking disk]

Inserting an EXH blocking disk in the exhaust passage of a manifold valve can separate the exhaust from the valve so it does not affect the other valves. It can also be used in positive pressure and vacuum pressure mixed manifolds. (2 pieces are required to block both the EA and EB sides of the EXH.)


Series	SUP blocking disk	EXH blocking disk
JSY1000	JSY11M-40P-1A	JSY11M-40P-1A
JSY3000	JSY31M-40P-1A	JSY31M-40P-2A
JSY5000	JSY51M-40P-1A	JSY51M-40P-1A

If the blocking disk is ordered using the manifold specification sheet and ordered

at the same time as the manifold, the

#### Labels for blocking disks

These labels can be used to indicate and confirm where on the manifold the SUP/EXH blocking disk assemblies were inserted. (3 labels of each)




# Manifold Options JSY1000/3000/5000 Series

## **Dimensions: Manifold Options**


## Blanking plate








## **JSY3000** series





#### **JSY5000** series







**JSY5000** series

#### ■ Individual SUP/EXH spacer


## **JSY1000** series



Individual SUP/EXH spacer





**JSY3000** series



(SUP, EXH port) Applicable tubing O.D.: e6

42.9






**SMC** 


## **Dimensions: Manifold Options**

## SUP stop valve spacer with residual pressure release valve

\* Only compatible when the JSY1000 series 4(A), 2(B) ports are port size C6



SUP stop valve spacer with residual pressure release valve




**⊘**SMC


# JSY1000/3000/5000 Series Made to Order

Please contact SMC for detailed dimensions, specifications, and delivery times.





Be sure to select the power-saving circuit type when the JSY3000/5000 series is continuously energized for long periods of time. Be careful of the energizing time when the power-saving circuit is selected. Refer to page 158 for details. 0.1 W: JSY3000/5000





# JSY1000/3000/5000 Series Specific Product Precautions 1

Be sure to read this before handling the products.

Refer to page 7 for safety instructions and pages 8 to 14 for 3/4/5 port solenoid valve precautions.

#### Environment

# **M**Warning

- Do not use valves in atmospheres of corrosive gases, chemicals, sea water, water, water vapor, or where there is direct contact with any of these.
- Products compliant with IP67 enclosures (based on IEC 60529) are protected against dust and water, however, these products cannot be used in water. If using in an environment that is exposed to water and dust splashes, take measures such as using a protective cover.
- When using built-in silencer type manifold with an IP67 enclosure, keep the exhaust port of the silencer from coming into direct contact with water or other liquids.

Valve Mounting

## ▲Caution

Mount it so that there is no slippage or deformation in gaskets, and tighten with the tightening torque as shown on the right.

Series	Thread size	Tightening torque
JSY1000	M1.4	0.06 N·m
JSY3000	M2	0.16 N·m
JSY5000	M3	0.8 N·m

#### Manual Override

# **M**Warning

Manual override is used to switch the main valve without inputting an electrical signal for the valve. When manual operation is performed, the connected actuator will start operating, so be sure to confirm that it is safe to operate beforehand.

#### Non-locking push type


Push down on the manual override button until it stops.



#### ■ Push-turn locking slotted type [D type]

Push down on the manual override with a small flat head screwdriver until it stops, and then turn it  $90^{\circ}$  clockwise. The manual override is then locked. To release it, turn it counter-clockwise.

If it is not turned, it can be operated the same way as the non-locking push type.




#### Manual Override

## **≜** Warning

#### Push-turn locking lever type [E type] (Only for the JSY3000/5000)

Push down on the manual override by finger until it stops, and then turn it 60° clockwise. The manual override is then locked. To release it, turn it counterclockwise. If it is not turned, it can be operated the same way as the non-locking push type.



## ▲Caution

Do not apply excessive torque when turning the manual override. [0.1  $N{\cdot}m]$ 

When locking the manual override, be sure to push it down before turning. Turning without first pushing it down can cause damage to the manual override and other trouble such as air leakage, etc.

#### Used as a 3-Port Valve

## Caution

#### In case of using a 5-port valve as a 3-port valve

The JSY1000/3000/5000 series can be used as normally closed (N.C.) or normally open (N.O.) 3-port port valves by closing one of the cylinder ports 4(A) or 2(B) with a plug. However, they should be used with the exhaust ports kept open. Use them when a double solenoid type 3-port valve is required.

Plu	g position	B port	A port
Туре	of actuation	N.C.	N.O.
solenoids	Single	(A)4 2(B) [ZE] 1 4 (EA)5 1 3(EB) (P)	(A)4_2(B) [ZEA] (A)4 (EA)5_1_3(EB) (P)
Number of solenoids	Double	(A)4 2(B) [건도[시] (A]3 (EA)5 1 3(EB) (P)	(A)4_2(B) [건호[사] / [건작되 (EA)5 1 3(EB) (P)



# JSY1000/3000/5000 Series **Specific Product Precautions 2**

Be sure to read this before handling the products.


Refer to page 7 for safety instructions and pages 8 to 14 for 3/4/5 port solenoid valve precautions.

### Light/Surge Voltage Suppressor

## ▲Caution


Polar type Positive common

Light/surge voltage suppressor (
Z)



#### Positive common Double solenoid. 3-position, 4-position

Light/surge voltage suppressor (
Z)



#### Non-polar type

COM

(+,-)<sup>C</sup>

Varisto

SOL.a

(-.+

With light/surge voltage suppressor (
U)

Single solenoid




\* Non-polar type is not available for the JSY1000.

## With power-saving circuit

#### (JSY3000/5000 series products are made to order.)

Power consumption is decreased to approx. 1/2.5 to 1/4 of the amount consumed at startup by reducing the wattage required to hold the valve in an energized state. (Effective energizing time is over 67 ms at 24 VDC.)



Negative common Single solenoid

Light/surge voltage suppressor (
NZ)




Negative common

Double solenoid. 3-position, 4-position

Light/surge voltage suppressor (
NZ) [SOL.b] LED 38 COM 0 [SOL.a (+ Polarity protection diode

The circuit shown to the left reduces the power consumption for holding in order to save energy. Refer to the electrical power waveform as shown below.

#### <Electrical power waveform with power-saving circuit>



· Since the voltage will drop by approx. 0.5 V due to the transistor, pay attention to the allowable voltage fluctuation. (For details, refer to the solenoid specifications of each type of valve.)

#### Residual voltage of the surge voltage suppressor

If a varistor or diode surge voltage suppressor is used, there is some residual voltage to the protection element and rated voltage. Therefore, refer to the table below and pay attention to the surge voltage protection on the controller side. Also, since the response time does change, refer to the valve specifications on page 35.

#### Residual Voltage

Surge voltage suppressor	24 VDC
Z	Approx. 1 V
U	Approx. 47 V

#### **Continuous Duty**

## ▲ Caution

If a valve is energized continuously for long periods of time, the rise in temperature due to heat-up of the coil assembly may cause a decline in solenoid valve performance, reduce service life, or have adverse effects on peripheral equipment. If the valve is energized continuously for long periods of time, be sure to use a valve with power-saving circuit. In particular, if three or more adjacent stations on the manifold are energized simultaneously for extended periods of time or if the valves on A side and B side are energized simultaneously for long periods of time, take special care as the temperature rise will be greater.

#### Energization of a 2-Position Double Solenoid Valve

## A Caution

To avoid operation failure, do not energize the A side and B side of 2-position double solenoid valve at the same time.

Single solenoid





# JSY1000/3000/5000 Series Specific Product Precautions 3

Be sure to read this before handling the products.

Refer to page 7 for safety instructions and pages 8 to 14 for 3/4/5 port solenoid valve precautions.

Countermeasure for Surge Voltage Intrusion

# **▲**Caution

#### Surge voltage intrusion

With non-polar type valves, at times of sudden interruption of the loading power supply, such as emergency shutdown, surge voltage intrusion may be generated from loading equipment with a large capacity (power consumption), and the valve in a de-energized state may switch over (see Figure 1). When installing a breaker circuit for the loading power supply, consider using a valve with polarity (with polarity protection diode), or install a surge absorption diode between the loading equipment COM line and the output equipment COM line (see Figure 2).





Figure 1. Surge intrusion circuit example (NPN outlet example) (24 VDC)




Light Indication

## **≜**Caution

When equipped with indicator light and surge voltage suppressor, the light window turns orange when solenoid a is energized, and it turns green when solenoid b is energized.

<JSY1000 series>

<JSY3000/5000 series>




### Changing Connector Entry Direction

# ▲Caution

Connector direction for electrical entry of D-sub connector and flat ribbon cable <|P40> can be changed. If the directional change is required, slide the lever on the side of the connector block to the FREE position, and then change the direction as shown in the figure. Also, before connecting the connector, be sure to return the lever to the LOCK position. (If the lever is difficult to slide, move the connector a little bit to make it easier to slide the lever.)

If an excessive force is applied on the connector in the LOCK position, the connector block may be damaged. Also, using in such a way that the connector floats in the FREE position, it may cause the lead wire, etc., to break.

\* Direction cannot be changed for D-sub connector <IP67> or compact type.





# JSY1000/3000/5000 Series Specific Product Precautions 4

Be sure to read this before handling the products.


Refer to page 7 for safety instructions and pages 8 to 14 for 3/4/5 port solenoid valve precautions.

#### Manifold Indication Symbol

# **≜**Caution

The letter "[S]" is indicated on manifold blocks for the JSY series as shown below. This indication refers to the type of substrate (single wiring) inside the manifold blocks. When there is no symbol, double wiring is used.

When the manifold specification sheet does not include a wiring specification, all stations will be double wiring specification. In this case, single and double solenoid valves can be mounted in any position, but when a single valve is used, there will be an unused control signal. To avoid this, indicate positions of manifold blocks for single wiring specification and double wiring specification on a manifold specification sheet. (Note that double, 3- or 4-position valves cannot be used for manifolds blocks with single wiring specification [S].)



#### Substrate inside Manifolds

## ▲Caution

The substrate inside of manifolds cannot be taken apart. Attempting to do so may damage parts.

### Securing the DIN Rail Mounting Type Manifold

# **≜**Caution

- When the manifold is secured with bolts on a mounting surface, etc., it can be operated just by securing both ends of the DIN rail if the bottom surface of the DIN rail is entirely in contact with the mounting surface when mounted horizontally. However, if it is used with other mounting or with side or reverse mounting, secure the DIN rail with bolts at regular intervals. As a guide, insert bolts in 2 locations for 2-5 stations, 3 locations for 6-10 stations, 4 locations for 21-24 stations.
- 2. When using the manifold with DIN rail in an environment where any vibration or impact is applied to it, the DIN rail itself may be broken. In particular, if the installation surface vibrates when mounting the manifold on the wall or if a load is directly applied to the manifold, the DIN rail may be broken, causing the manifold to drop. When any vibration, impact, or load is applied to the manifold, be sure to use the direct mounting manifold.


#### How to Replace One-touch Fittings

## **≜**Caution

By replacing One-touch fittings of manifold base, it is possible to change the connection diameter of the 4(A), 2(B), 1(P), 3/5(E) ports. When replacing the One-touch fittings, remove the clip or the plate before pulling the One-touch fittings off. Mount the One-touch fittings by following the removal procedure in reverse.

Use caution as it may cause air leakage if the clip and the plate are not inserted securely enough when they are switched. Refer to page 151 for part numbers of One-touch fittings.

#### Connector connecting base



## <Assembly method>

#### · SUP/EXH (end) block

Fitting direction is specified when the fittings below are used. Assemble the fitting so that the D-cut surfaces of the fitting face <u>up and down</u>.

numbers

Fitting part no.: KQSY30-C8-X1336 (JSY1000) KQSY50-C12-X1336 (JSY5000)

#### Manifold block

Assemble the fitting so that the D-cut surfaces of the fitting face sideways.

Fitting part no.: KQSY10-C4-X1336 (JSY1000)

KQSY11-C6-X1336 (JSY1000) KQSY30-C8-X1336 (JSY3000) KQSY50-C12-X1336 (JSY5000)





# JSY1000/3000/5000 Series **Specific Product Precautions 5**

Be sure to read this before handling the products.

Refer to page 7 for safety instructions and pages 8 to 14 for 3/4/5 port solenoid valve precautions.

Other	Tube	Brands
-------	------	--------

# ▲ Caution

#### 1. When using other than SMC brand tube, confirm that the following specifications are satisfied with respect to the tube outside diameter tolerance.

1) Nylon tube	within ±0
2) Soft nylon tube	within ±0
3) Polyurethane tube	within +0
	within _(

0 1 mm 0.1 mm 0.15 mm -0.2 mm

Do not use tube which do not meet these outside diameter tolerances. It may not be possible to connect them, or they may cause other trouble, such as air leakage or the tube pulling out after connection.

#### **One-touch Fittings**

## **∧** Caution

## Tube attachment/detachment for One-touch fittings

- 1) Tube attachment
  - 1. Take a tube having no flaws on its periphery and cut it off at a right angle. When cutting the tube, use tube cutters TK-1, 2, or 3. Do not use pliers, nippers, scissors, etc. If cutting is done with tools other than tube cutters, the tube may be cut diagonally or become flattened, etc., making a secure installation impossible, and causing problems such as the tube pulling out after installation or air leakage. Allow some extra length in the tube.
  - 2. Grasp the tube and push it in slowly, inserting it securely all the way into the fitting.
  - 3. After inserting the tube, pull on it lightly to confirm that it will not come out. If it is not installed securely all the way into the fitting, this can cause problems such as air leakage or the tube pulling out.

#### 2) Tube detachment


Use the release tool when the removal of tube is difficult due to the tube size. Refer to page 151 for releasing tools

- 1. Push in the release button sufficiently, pushing its collar equally around the circumference.
- 2. Pull out the tube while holding down the release button so that it does not come out. If the release button is not pressed down sufficiently, there will be increased bite on the tube and it will become more difficult to pull it out.
- 3. When the removed tube is to be used again, cut off the portion which has been chewed before reusing it. If the chewed portion of the tube is used as is, this can cause trouble such as air leakage or difficulty in removing the tube

#### Fixing Method of JSY1000 Series Clamp Bracket

## ∕**≜ Caution**

The clamp bracket fixing method for the JSY1000 series is different depending on wiring. Clamp bracket holding screw



# ▲ Caution

Even though the inlet pressure is within the operating pressure range, when the piping diameter is restricted due to size reduction of supply port (P), the flow will be insufficient. In this case, the valve does not switch completely and the cylinder may malfunction

Installation

#### Trademark

DeviceNet® is a registered trademark of ODVA, Inc.

EtherNet/IP® is a registered trademark of ODVA, Inc.

CompoNet® is a registered trademark of ODVA. Inc.

EtherCAT® is registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.



Manifold Option How to Order Spacer Type Ejector (With mounting screw)




Spacer Type Ejector JSY11M-EP-3A-07SC6-N



## 2 Body type

Symbol	Body type	
1 Supply valve (N.C.)		
2 Supply valve (N.O.)		
3 Supply valve (N.C.)/Release valve (N.C.)		

<b>3</b> Nominal nozzle size				
07	ø0.7			
10	ø1.0			



### 5 Exhaust type

Cumhal	Exhaust ture	
Symbol	Exhaust type	Element
Nil Silencer		Without
C6 ø6 One-touch fitting		—

Spacer Type Ejector is connection to both A port and B port. (See p. 161-4 circuit diagram). One of them can be connected to vacuum pad and the other to pressure switch without a branch piping to manifold. When only one of them is turned piping, be sure to turn plug the unused port.

<b>6</b> Vacuum break flow adjusting unit		
Nil	Without	
N	With (Only with body model "3" Release valve)	

 Refer to "Ejector Specifications" on page 161-2 for the max. number of ejector stations that can operate simultaneously.


The following solenoid is recommended for mounting of spacer type ejector.

### Ejector Supply Valve/Release Valve

JSY1000 Se	eries
------------	-------

JSY <u>1300T-5</u> Z		
00	6	456
Base mounted • • With power-saving cir		With power-saving circuit





3 Pilot valve exhaust method		
0	Pilot valve individual exhaust	

4 Rated voltage	
5	24 VDC

### Type of actuation

Symbol	Type of actuation		Applicable spacer type ejector body type symbol
1	2-position	Single	1.2
2	2-position	Double	1, 2
3	3-position	Closed center	3

#### 5 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification
Z			Positive common
NZ	•		Negative common


\* When SI unit is used

Select a valve from Z when the SI Unit output polarity is Nil (positive common).

Select a valve from NZ when the SI Unit output polarity is N (negative common).



## 6 Manual override



\* When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the ejector, please order the base gasket separately if it is needed for maintenance. Refer to page 161-8 for base gasket and mounting screw part numbers.



\_\_\_\_

# JSY1000 Series Spacer Type Ejector



## Ejector Specifications\*1,\*2

Model	Standard supply pressure [MPa]	Nominal nozzle size [mm]	Supply pressure range [MPa]	Achievable vacuum pressure [kPa] Type S	Max. suction flow [L/min (ANR)] Type S	Air consumption [L/min (ANR)]	Noise level*3, *4 [dB (A)]
JSY11M-EP-		07		Type 5		27	68
JSY11M-EP-DA-10SD	0.45	0.7	0.1 to 0.6	-90	11.5	21	00
	0.45	1.0		-90	21	52	80

\*1 The values indicating characteristics are representative values and may vary depending on the atmospheric pressure (weather, altitude, etc.).

\*2 Value at supply pressure.

\*3 Actual values under SMC's measurement conditions (Not guaranteed values)

\*4 This is a value obtained with a single ejector performing vacuum suction in the silencer air discharge system.

### Max. Number of Manifold Stations that Can Operate Simultaneously [units]

Model	Max. number of manifold stations that can operate simultaneously [units]*1, *2, *3					
Woder	U or D side Air supply to one side	U and D side Air supply to both sides				
JSY11M-EP-□A-07S□	8	12				
JSY11M-EP-DA-10SD	2	4				

\*1 Value at supply pressure.

\*2 Actual values under SMC's measurement conditions (Not guaranteed values)

\*3 This is the maximum number of stations that can simultaneously operate when vacuum is simultaneously generated by the ejectors only (excluding the solenoid valve for actuator). When a solenoid valve for actuator and a spacer type ejector are mounted on the same manifold, simultaneously operating them may affect each other and degrade their performances. As a countermeasure against this problem, by using a single SUP spacer (mountable only on the solenoid valve for actuator) and a SUP blocking disk, separate air supply to those components (refer to pages 153 and 154).

### Weight

Spacer type Ejector model	Exhaust type	Vacuum break flow adjusting unit	Weight [g]
JSY11M-EP-□A-□S	Silencer exhaust		16
JSY11M-EP-□A-□SC6	ø6 One-touch fitting	Without	20
JSY11M-EP-DA-DS-N	Silencer exhaust		23
JSY11M-EP-□A-□SC6-N	ø6 One-touch fitting	With	27

### Solenoid Valve (Supply Valve/Release Valve) Flow Rate Characteristics

	Port	size	Valve flow rate characteristics						
Valve model	1, 3/5 (P, E)	4, 2 (A, B)	Passage C [dm³/(s·b		b				
JSY1100	C8	C6	$1 \rightarrow 4/2 \ (P \rightarrow A/B)$	0.96	0.30				
JSY1200			$4/2 \rightarrow 3/5 (A/B \rightarrow E)$	0.91	0.48				
JSY1300	0		$1 \rightarrow 4/2 \ (P \rightarrow A/B)$	0.64	0.37				
3311300			$4/2 \rightarrow 3/5 (A/B \rightarrow E)$	0.66	0.46				


\* Calculation of effective area S and sonic conductance C: S = 5.0 x C


\* Values measured in accordance with ISO 6358:1989, JIS B 8390:2000

\* Characteristics in solenoid valve JSY1000 series single unit.

## **Exhaust Characteristics/Flow Rate Characteristics**


(Exhaust characteristics: Supply pressure 0.45 MPa)






### Release Flow Rate Characteristics The graph when vacuum release flow adusting needle is from fully closed to open in supply pressure 0.45 MPa.

#### Nominal Nozzle Size Ø0.7 Specification




It is the vacuum release flow rate from one of the two vacuum port (A, B port). The other is turned plug.

Nominal Nozzle Size ø1.0 Specification



# Spacer Type Ejector JSY1000 Series


## Construction



#### Material Body Resin 1 Resin 2 Nozzle 3 Diffuser Resin 4 Silencer Resin 5 Clip Stainless steel HNBR 6 Base gasket Needle block 7 Resin Needle Resin 8 9 Knob Resin Needle guide 10 Brass 11 Lock pin Stainless steel Resin 12 Plug-in spacer NBR O-ring


## **Circuit Diagrams**

### JSY11M-EP-1A-OS




\* The valves in the above circuit diagram are examples.

#### JSY11M-EP-3A-OS




#### JSY11M-EP-2A-OS




\* The valves in the above circuit diagram are examples.

#### JSY11M-EP-3A-DSD-N



## How to Order Manifold Assembly (When mixed manifold block range 6.5 mm/9 mm is used)

#### Example (JJ5SY1-10F1-D-CM)



· For the valve arrangement, the valves closest to the D side are considered the 1st stations respectively.

· Below the manifold part number, write down the valves and spacer type ejectors to be mounted in order from the first station as shown in the figure.

· Write down spacer type ejectors next to the valves they are to be combined with.

· Spacer type ejector can only be mounted on 9 mm wide manifold block.

· If the layout is complicated or you want to specify a desired layout, please specify it by means of the manifold specification sheet.

#### Example of Manifold Specification Sheet Entry


			D si	de	1	2	3	4	5	6	24	U side
del		(J) JSY1000 series			1	3						
Type of actuation		(K) Ejector Supply/Release valve					1	1	3			
Va	(L) Internal pilot		]	[								] /
		(N) Body type					1	1	3			
	Spacer type ejector model	(O) Nominal nozzle size	]	[			07	07	07			
	Spacer type ejector model	(P) Exhaust type		[			C6					
_		(Q) Vacuum break flow adjusting unit							N			
d option	Blanking plate JSY11M-26P-1A											
Manifold	Jo Individual SUP spacer JSY11M-38P-1A-C4											
– Omission –		1				-	Omiss	ion –			1/	
	(G) A, B port size	A, B port	]		C4	C4	C6	C6	C6			]/
	Dium	A port		I								
	Plug	B port		I					С			

Order procedure of the above order example indicates that vacuum port of spacer type ejector is either A or B port. When only one vacuum port is desired, manifold specification sheet must be used to specify plug. It shows the manifold specification sheet in which plug is specified on B port of the fifth station.



# Spacer Type Ejector JSY1000 Series

## How to Order Manifold Assembly (For manifold block Width 9 mm only)




Below the manifold part number, write down the valves and spacer type ejectors to be mounted in order from the first station as shown in the figure.

Write down spacer type ejectors next to the valves they are to be combined with.
 Spacer type ejector can only be mounted on 9 mm wide manifold block.


If the layout is complicated or you want to specify a desired layout, please specify it by means of the manifold specification sheet.

## **Dimensions: Spacer Type Ejector**



# Spacer Type Ejector JSY1000 Series

## Order parts for Spacer Type Ejector



No.	Description	Part no.	Note			
1	Spacer type ejector mounting screw (M1.4 x 4.5)	Z2-SR1-A	10 pcs. (for 5 ejectors) Hexagon socket head cap screw (Hexagon width across flats: 0.9 mm)			
2	Base gasket	JSY11M-9P-1A	10 pcs.			
3	Silencer	Z2-SC1-A	The part number is for 1 piece.			
4	One-touch fitting assembly (ø6)	KQSY11-C6-X1336	The part number is for 1 piece. (Sales unit: 10 pcs.)			
5	Clip	Z2-CL1-A	The part number is for 1 piece.			
6	Valve mounting screw (M1.4 x 21.5)	JSY11V-23-1A	20 pcs. (for 10 valves)			
0	Vacuum break flow adjusting unit	Z2-NU1-A	Plug-in spacer assembly, (8) mounting screw (2 pcs.) included			
8	Valve/Unit mounting screw (M1.4 x 31.5)	JSY11V-23-2A	2 pcs. (1 unit).			



# JSY1000 Series Spacer Type Ejector/Specific Product Precautions 1

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve and vacuum equipment precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

### Spacer Type Ejector

**Design / Selection** 

# **M**Warning

#### 1. Vacuum adsorption

At the time of vacuum adsorption, be sure to supply a constant supply of vacuum. Failure to do so may result in foreign matter sticking to the adsorption pad or air leakage, causing the workpiece to drop.

#### 2. Ventilation

Provide ventilation when using a spacer type ejector in a confined area, such as in a closed control panel. For example, install a ventilation opening, etc., in order to prevent pressure from increasing inside of the confined area and to release the heat generated by the valve.

#### 3. Mounting the suction filter

This product is not mounted with a suction filter. The vacuum ejector suctions surrounding dust and water droplets during suctioning of the workpiece. Therefore, it is necessary to avoid the entry of the dust and water droplets into the product. We recommend that you separately install a suction filter in the vacuum side piping. If water droplets or others could be suctioned, please consider installation of a drain separator for vacuum or the like.

#### 4. Vacuum holding

Since valves are subject to air leakage, they cannot be used for applications such as holding vacuum in a pressure vessel. SMC can issue no guarantees regarding the maintenance of workpiece adsorption when using check valves. Take separate safety measures to prevent workpieces from dropping in the case of an electrical power outage, etc.

#### Exhaust / Exhaust Noise

## 

#### 1. Exhaust


The exhaust resistance should be as small as possible to obtain the full spacer type ejector performance. There should be no shield around the exhaust slit for silencer exhaust type.

Exhaust / Exhaust Noise

## ▲Caution

### 2. Exhaust noise

When spacer type ejector generates vacuum, noise can be heard from the exhaust port when the standard supply pressure is close to the pressure that generates peak vacuum pressure making vacuum pressure unstable. If the vacuum pressure range is adequate for adsorption, there should not be a problem. If the noise causes a problem or affects the setting of the SI Unit, change the supply pressure slightly to avoid the pressure range of the noise.



#### 3. Exhaust air

If solid substances are sucked in through the vacuum (A, B) port, they will be discharged from the exhaust port at a high speed if the exhaust (EXH) port is opened. Therefore, do not look into the exhaust port or direct the exhaust port toward a person when the spacer type ejector is operating.

### How to Mount the Product

## Caution

1. Do not drop, hit, or apply excessive impact to the product when handling it.

Even if the body looks undamaged, the internal components may be damaged, leading to a malfunction.

2. Load to the body

The product body is made of resin; therefore, do not apply load to the port after mounting. Prevent any kind of operation which generates moment as this may cause reduced performance or damage to the body.





## JSY1000 Series Spacer Type Ejector/Specific Product Precautions 2

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve and vacuum equipment precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Spacer Type Ejector

Piping

## **≜**Caution

When piping to the product, be careful not to confuse the vacuum port (A, B port) with the exhaust port of the spacer type ejector. Otherwise this can result in damage or reduced performance. Apply compressed air after confirming that the piping is connected correctly.

If each exhaust piping for the port exhaust ejectors are connected and made into centralized piping, the exhausted air will flow back into the exhaust path which is not operating, and will then be exhausted from the vacuum port. Exhaust individually.

### Air Consumption

## **∆**Caution

When the spacer type ejector is generating vacuum, air is consumed. Therefore, if the air supply capacity is insufficient, the supply pressure may drop. As a guide for sufficient air supply capacity, we recommend that you secure a supply capacity three times or more the air consumption of the ejector.

