

## **Certificate of Compliance**

	Akihabara UDX 15F 4-14-1 Sotokanda Chiyoda-ku, Tokyo 101-0021 Japan Attention: Kaoru Nakamura
Issued to:	SMC Corporation
Project:	2716553
Certificate:	2201234

Master Contract: 176385

Date Issued:

April 17, 2014

## The products listed below are eligible to bear the CSA Mark shown



Rícardo Sanchez Issued by: Ricardo Sanchez

## PRODUCTS

CLASS 3231 02 - SWITCHES - Automatic - Pressure Type

Pressure switch, enclosed, ISG Series, max rating: 10A resistive 220Vac; 12A 110Vac; 3A 24Vdc.

Notes:

Note: The above devices are enclosed in a general purpose enclosure with provisions for conduit entry.

## APPLICABLE REQUIREMENTS

CSA - C22.2 No. 14

Industrial Control Equipment